



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/564

To

Dated: 03 / 07 / 2025

The Assistant Engineer (E),
Sub-Division-4, Edu. Elect. Edn.-1, Div, (N)
PWD, Govt. of Delhi Room No. 03, First Floor,
Plot No-41, Rama Road, Zakhira, Delhi-110015.

Sub: Regarding issuance of fire safety certificate in r/o Govt. Sarvodaya Vidyalaya (School ID No- 1207032) located at Lancer Road, Near Vishwavidyalaya Metro Station, Delhi-110007.

Sir,

Please refer to your letter received through online e-mail dated: 25/06/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 27/06/2025 in the presence of Sh. Shyam Singh (Guard) and building was comprised of 01 New block, ground & 03 upper floors only to verify the compliance of the shortcomings/ observations already communicated by this department vide letter of even no.F6/DFS/MS/2025/School/356 dated 07/05/2025 and observed that the shortcomings have not been removed so far, (Copy enclosed).

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
(Director)

Ph:-011-23414000

Copy to:-

1. Principal, Govt. Sarvodaya Vidyalaya (School ID No- 1207032) located at Lancer Road, Near Vishwavidyalaya Metro Station, Delhi-110007.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 356

Dated: 07/05/2025

To

The Assistant Engineer (E),
Sub-Division-4, Edu. Elect. Edn.-1, Div, (N)
PWD, Govt. of Delhi Room No. 03, First Floor,
Plot No-41, Rama Road, Zakhira, Delhi-110015.

Sub: Regarding issuance of fire safety certificate in r/o Govt. Sarvodaya Vidyalaya (School ID No- 1207032) located at Lancer Road, Near Vishwavidyalaya Metro Station, Delhi-110007.

Sir,

Please refer to your letter No.54(45)/A.E.(E)-4/P.W.D/M-1/2024-25/05 dated: 10/03/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/04/2025 to verify the fire safety measures issued vide NBC Part-IV/UBBL-2016 and observed that the building was comprised of ground & 03 upper floors only. At the time of inspection Sh. Pradeep Kumar (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 Hose reel hose is provided but not functional and all hose reel nozzles found missing.
- 2 Terrace level fire fighting pump capacity of 450lpm is provided but not functional.
- 3 Terrace level water tank for firefighting capacity of 10,000 ltrs is provided but domestic connection is provided.
- 4 Exit signage is not provided at strategic locations in the school building.
- 5 Standby power supply is not provided.
- 6 Electrical panel below staircase needs to be removed/shifted in a safer place.
- 7 As built plan of the new school building shall also be submitted.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of new school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:- 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. Principal, Govt. Sarvodaya Vidyalaya (School ID No- 1207032) located at Lancer Road, Near Vishwavidyalaya Metro Station, Delhi-110007.