

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTER: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/WZ/2025/286

Dated: 26/03/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya Located at S.P. Road, Nangloi, Delhi-110041, comprised of 02 blocks of Ground + 03 Upper Floors only, owned/occupied by Sarvodaya Kanya Vidyalaya, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/WZ/2022/School/39 dated 14/01/2022. The said premises was re-inspected by the officer concerned of this department on 10/03/2025 in the presence of Sh. Satveer Singh (Estate Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 26/03/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on .26/03/2625. at New Delhi by.

(Axil Garg) Director Tel No. 011-23414000

Copy to: -

The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.

2. The Principal, Sarvodaya Kanya Vidyalaya, S.P. Road, Nangloi, New Delhi-110041.

Conditions for the validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.

 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.

3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.

4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.

- 5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
- 6. All comments / directions of licensing Department shall always be permitted and followed.
- 7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
- 8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

 Name and address of the building: Sarvodaya Kanya Vidyalaya located at S.P. Road, Nangloi, Delhi-110041

2. Type of Occupancy : Educational.

3. Type of Case : Renewal

4. Details of previous NOC : F6/DFS/MS/WZ/2022/School/39 dated 14/01/2022

5. Fire Safety directives Letter No. : Nil

6. Date of inspection : 10/03/2025

7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)

8. Name and designation of Officer

from the building side : Sh. Satveer Singh (Estate Manager)

9. Year of Construction : 2021

10. Applicant's letter No. : email dated 13/01/2025

This school building is comprised of 02 blocks - G+03 Upper Floors.

3	Minimum standards on fire prevention and fire safety U/R 33	Requirem	ents	Provided at site	Remarks MR/NMR
1.	Access of building • Road width	06 m 4.5 m		Provided Provided	MR MR
1	 Gate width Width of internal road	N	٨	NA	NA
2.	Number, width, Type & Arrang	ements of e	xits		
	 a. Number of staircases Upper floors Basements Width of staircases Upper floors Basements Protection of exits Fire check door Pressurization No of continuous staircase to terrace 	02 in cac		02 in 1 st block & 03 in 2 nd block	
ı		NA		NA	NA
		1.5 m	1 st block 2 nd block	k - 1.76 m x 1 & 1.75 m x 1 ck - 1.80 m x 1, 1.73 m x 1 & 1.67 m x 1	
		1	١٨	NA	NA
		N.		NA NA	NA NA
		01 in	cach	1 st block - 02 2 nd block - 03	NΛ
	c. Width Of Corridor	1.5	m m	Provided Provided	MR MR
1.	Compartmentation • Fire check door	N	Λ	NΛ	NA
	Scaling of electrical shafts Fire Rating of shaft door	N	Λ	NA	NΛ
		N	٨	NA	NΛ
	Water Curtain	N	Λ	NΛ	NΛ
	Fire Dampers	N	iA	NΛ	NA
4.	Smoke managements System	1	iΛ	NΛ	NA
	Basements Upper floors		IA	NΛ	NA

2		
		•
	-	•

	N-26					
5.	Fire Extinguishers		7	1		
	 Total numbers 	20 nos.	42 nos.	MR		
	• Types	ABC & CO ₂	Provided	MR		
,	IS marking	ISI marked	Provided	MR		
6.	First Aid Hose Reels		Control of the contro			
	 Total numbers on each floor 	01 in each block	Provided	MR		
	 Length of hose reel hose 	30 m	Provided	MR		
7.	Nozzle diameter	5 mm	Provided	MR		
1.	Automatic fire detection and alarming	system				
	Type of detectors	NΛ	NΛ	NΛ		
	Location of Main Panel	NΛ	NΛ	NA		
	Location of Repeater Panel	NΛ	NΛ	NΛ		
	Alternate source of powerHooters' Location	NΛ	NΛ	NΛ		
8.	MOEFA	NΛ	NΛ	NΛ		
9.		NΛ	NΛ	NA		
10.	Public Address System	NΛ	NΛ	NΛ		
	Automatic Sprinkler System Basements	le				
		NΛ	NΛ	NΛ		
	Upper Floor Sprinkler above felor as it.	NΛ	NA	NΛ		
11.	Sprinkler above false ceiling Internal Hydrants:	NΛ	NΛ	NΛ		
	Size of riser/down- comer					
	Number of budgets	NA NA	NA	NA		
	Number of hydrants per floorHose Box	NA NA	NA	NΛ		
12.	Yard Hydrants	NA	NA	NΛ		
12.						
	Total number of hydrantsHose Box	NΛ	NΛ	NΛ		
13.		NA	NA	NA		
	Pumping Arrangements:					
	Ground Level Discharge of main nump	NIA I	N. C. C.			
	is is charge of main pump	NΛ	NA	NΛ		
	Head of main pumpNumber of main pumps	NΛ	NA	NA		
	Jockey pump out put	NΛ	NA	NA		
	Jockey pump head	NA NA	NA NA	NΛ		
	Standby Pump out put	NΛ	NA NA	NΛ		
	Standby Pump Head	NA NA	NΛ	NA		
	> Auto Staring/Manual	NA NA	NΛ	NΛ		
	stopping	18/1	NA	NA		
	> Pump House Access	NΛ	NA	NΛ		
	Terrace level	1875	INZ	INA		
	Discharge of pump	450 lpm	Provided	MR		
	> Head of the pump	430 ipm 40 m	Provided	MR		
	> Power supply	Required	Provided			
	> Auto starting of pump		2000 2000 10 Sept. 2000	MR		
4.		Required .	Provided	MR		
*-	Captive water Storage for fire fighting	NA	NΛ	NΛ		
	 Under ground tank capacity Draw off connection 			NA NA		
		NA NA	NΛ			
	Fire service inlet	NA NA	NA NA	NΛ		
	Access to tank	NA 10,000 ltm	NA Provided	NA MB		
	Overhead Tank capacity	10,000 ltrs	Provided	MR		
5	Exit Signage	Required	Provided	MR		
).	Provision of Lifts	المسار والكار	,	-		
	> Pressurization of Lift Shaft	NΛ	NA NA	NΛ		
	 Pressurization of lift lobby 	NΛ	NΛ	NA		
	Communication in lift Car	NΛ .	NΛ	NΛ		
1	➤ Fireman's Grounding Switch	NΛ	NA	NA		
1	➤ Lift Signage	NA	NA	NΛ		
11		NΛ	NA	NA		
	Standby power supply					

Refuge Area	NΛ	NA	NA.
> Total area	NΛ	NA	NA
> Location	11//	V. 1000	
Fire control room	NΛ	NΛ	NA
> Detector system panel	NΛ	NA	NΛ
> Flow Switch Panel	NA	NΛ	NΛ
> PA System Panel	NΛ	NΛ	NΛ
> Battery backup	NΛ	NΛ	NΛ
> Building Floor Plans		NA	NΛ
Special Fire Protection Systems for Protection of special Risks, if any;	NΛ		

Fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no. F6/DFS/MS/WZ/2024/662 dated 26/09/2024 found rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/WZ/2022/School/39 dated 14/01/2022 renewal under rule 35 of the Delhi Fire Service Rule 2010, is recommended.

Accordingly, DFA is prepared & put up for approval please.

ADO (JWP)

for your kind persual & Signatur Mease. 1913/2008