

248

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/NDZ/2025/ 861

Dated:- 03.07.2025

FIRE SAFETY CERTIFICATE

Certified that the block A of Govt. Sarvodaya Bal Vidyalaya, West Patel Nagar New Delhi-110008, comprised of ground plus three upper floors (newly constructed block A), was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/SZ/2022/992 dated 13/09/2022. Now, the premises was re-inspected by the officer concerned of this department on 26-06-2025 in the presence of M. Mahesh Sharma and found that the said school block has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B "Educational Building" (Sub-Div. B-I), Block A, ground plus three upper floors only with effect from03.07.2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on03.07.2025 at New Delhi by.

(Atul Garg)
DIRECTOR
 Delhi Fire Service

Copy to:-

1. The Commissioner , MCD Civic Centre New Delhi . to ensure in deviation in construction if any.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
3. The Principal, Govt. Sarvodaya Bal Vidyalaya, West Patel Nagar New Delhi-110008.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid only for Block A (new block),
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

21/36

INSPECTION REPORT

1. Name & address of the building:- Govt. Sarvodaya Bal Vidyalaya, West Patel Nagar New Delhi-110008
2. Type of occupancy:- Educational Building, ground plus three upper floors (newly constructed) block A
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/SZ/2022/992 dated 13/09/2022.
5. Fire safety directives No.- N/A
6. Date of inspection:- 26/06/25
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Mr. Mahesh Sharma
9. Year of construction:- block A- (2022),
10. Applicant's letter No:- letter no. GSBV/WPN/2025/73 dated 30.05.2025.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	requirements as per previous FSC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06	06 mtr.	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03	03	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	1.5 mtr each	1.70 mtr. each	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	04	04	MR
	E. Width of corridor	1.5 mts	1.80 mts.	MR
	F. Door size	1.20 mts	1.20 mts at each class room	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH (NA)	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	40 Nos.	MR

N/32

14.

	2) Types	ABC & CO2	ABC, CO2	
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			MR
	1) Total number of each floor	04	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM X 2 nos.	MR
	b) Head of pump	40 mts each	40 mts	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	05 nos.	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000	20,000 lts	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: DCP, CO ₂			MR

The fire protection system provided in the block -A (new block) in school building were tested, checked at random and found functional at the time of inspection

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/School/SZ/2022/992 dated 13/09/2022, under Rule 35(6) of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer

[Signature]
27/6/25

Name: - Sh. Ravinder Singh
Designation: ADO (CC)

[Signature]
27/6

[Signature]