



c/24

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2025/ 109

Dated: 14/02/2025

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Khyala, New Delhi- 110018.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Kanya Vidyalaya, located at Khyala (New Building), New Delhi- 110018. (School ID -1514013)

Sir,

This is in reference to your Email dated 16/01/2025, on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 04/02/2025 in presence of Smt. Monika Budgurjar (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is running in Ground + 03 Upper Floors, was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/28 dated 12/01/2022. Fire safety arrangements Such as Fire Extinguishers, First -Aid hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. First Aid Hose Reels are provided but not functional.
2. Main fire pump of 450 LPM, is provided but not functional.
3. Exit Signage are found removed.

In view of above Shortcomings the application for Renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

o/c
13/2/2025