



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 239

Dated: 11 / 03 / 2025

FIRE SAFETY CERTIFICATE

Certified that Govt. Sarvodaya Kanya Vidyalaya (ID No. 1309167) located at Single Storey, Vijay Nagar, Delhi-110009 comprised of 02 blocks interconnected, Ground & 03 upper floors each owned/ occupied by Govt. Sarvodaya Kanya Vidyalaya was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/2022/School/WZ/259 dated 11.03.2022. The premise was inspected by the officer concerned of this department on 20.02.2025 in the presence of Smt. Alka Rani (Vice-Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "Group B Educational (School)" with effect from 11.03.2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 11/03/2025 at New Delhi

(Atul Garg)
Director
Ph: 011-23414000
11/03/25

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya (ID No. 1309167) located at Single Storey, Vijay Nagar, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya located at Vijay Nagar, Delhi-110007.
 2. Composition of building : 02 New Blocks Interconnected, Ground & 03 upper Floors.
 3. Type of Occupancy : Educational (School ID. No-1309167)
 4. Type of Case : Renewal
 5. Details of previous NOC : F6/DFS/MS/2022/School/WZ/259 dated 11.03.2022
 6. Fire Safety directives letter No : NBC Part-4
 7. Date of inspection : 20.02.2025 94
 8. Name of the Inspecting Officers : ADO (RN)
 9. Name and designation of officers
 from the building side : Smt. Alka Rani (Vice- Principal)
 10. Year of Construction : 2019-20
 11. Applicant's letter No. : Online E-mail dated: 17.02.2025

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV/UBBL-2016 Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.50m	4.50m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.70m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	03	03	MR
	e. Width of Corridor	1.5m	1.50	MR
	f. Door Size	1.20m	1.20m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	16nos	64nos	MR
	• Types	ABC/Co2	ABC-40/ Co2-24	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels			
	• Total numbers on each floor	03 each floor	Provided	MR

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	N/A		
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	NA	N/A	NA
	➤ Jockey pump head	NA	N/A	NA
	➤ Standby Pump out put	NA	N/A	NA
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM Each	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	N/A	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR Each	10,000 LTR Each	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4/UBBL-2016, the FSC issued vide letter of even no. F6/DFS/MS/2022/School/WZ/259 dated 11.03.2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO (RN)

D.B. Mukharjee (DO/NW)

DCFO/.....10.7.2022
 Dated.....5.7.2022

04/03/2021
 By Cfo

8/3/2025

Cfo
 6/3/2025

Director
 6/3/25

Am/En

conf. - P.T.O.