



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/School/ 582

Dated: 10/07/2025

To,

The Principal,
Govt. (Co-ed) Senior Secondary School,
Sultanpur Majra,
Delhi-110083.

Sub: Issue of FSC in r/o Govt. (Co-ed) Senior Secondary School, Sultanpur Majra, Delhi-83.

Sir,

Kindly refer to online e-mail dated 27.05.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **01.07.2025**, in presence of **Mr. Raj Kumar (HOS)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. First Aid hose reel A & B blocks not functional and hose reel nozzle missing at some place.
2. Terrace Fire pumps A & B blocks with capacity of 450 LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
[/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000
ne
ag