



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव


No. F6/DFS/MS/School/WZ/2025/ 994

Dated:- 13/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Co-ed. Vidyalaya (Without Auditorium) (ID-1617008) Located at B-4, Paschim Vihar, New Delhi-110063, comprised of Ground + 01 Upper Floor was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2022/536 Dated 17/05/2022. The said premise was re-inspected by the officer concerned of this department on 11/07/2025 in the presence of Dr. Rakesh Kumar (HOS) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 13/08/2025 for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on 13/08/2025 at New Delhi by.


12/08/2025
Virendra Singh
Chief Fire Officer

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Govt. Sarvodaya Co-ed. Vidyalaya (ID-1617008) Located at B-4, Paschim Vihar, New Delhi-110063.

Conditions for validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: Govt. Sarvodaya Co-ed. Vidyalaya (Without Auditorium) Located at B-4, Paschim Vihar, New Delhi-63
2. Type of Occupancy : Educational (G + 01 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2022/536 Dated 17/05/2022
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 11/07/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Dr. Rakesh Kumar, (HOS)
9. Year of Construction : 1988-89
10. Applicant's letter No. : SV/Coed/B-4/PV/1116 dated 28/05/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 16.04.2019/ as per earlier FSC issued dated 17/05/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m 4.5 m NA	Provided Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> Upper floors Basements b. Width of staircases <ul style="list-style-type: none"> Upper floors Basements c. Protection of exits <ul style="list-style-type: none"> Fire check door Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size	02 NA 1.5 m NA NA NA NA 1.5 m 1 m	04 NA 1.35 m x 4 NA NA NA NA Provided Double door in each class room	MR NA MR(Old Case) NA NA MR MR MR
3.	Compartmentation		NA	
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 nos. ABC & CO ₂ ISI marked	Provided Provided Provided	MR MR MR

N-20				
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

Fire Control Room			
19	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection. The shortcoming issued vide letter no. F6/DFS/MS/WZ/2025/411 dated 19/05/2025 found rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements as per D.O.E. Cr. No. 3298-3398 dated 01/03/2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2022/536 dated 17/05/2022 is **recommended**.

Accordingly DFA is prepared and put up for approval please.

Aman Kumar Lathar
ADO (JWP)

DCFO/721/14/25
Dated: 31/12/2025

DCFO/721/14/25

31/12/2025

CFD/
11/08/2025

Principal Director

CFD to Gen.

CFD/
11/08/2025

ADO (JWP)

Sir, F.S. letter is put-up for your signature pl.

CFD/

11/08/25

11/08/25
ADO (JWP)

MS