

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 547

Dated: 24/06/2025

To,

The Principal,
Govt. Girls Sr. Sec. School No. 1,
Najafgarh, New Delhi-110043.

Sub: -Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Govt. Girls Sr. Sec. School No. 1 at Najafgarh, New Delhi-110043.

Sir,

Please refer to your letter No. GGSSNo.1/Njf/177, dated 24.04.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 09.06.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Alka Yadav (Principal) was present and it was observed that the school having two blocks, namely Main Block is comprised of ground plus three upper floors and Primary Block is comprised of ground plus one upper floors, and have following shortcomings:-

1. Hose reels found provided but not functional.
2. Terrace fire pump of 450 LPM × 2 found provided but not functional.
3. Overhead water storage tank of 8,000 ltrs. found provided against requirement capacity of 10,000 ltrs.
4. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

(Atul Garg)

Director
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.