



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

449
2025

No. F6/DFS/MS/WZ/School/2025/ 567
To,

Dated: 03/07/2025

The Assistant Engineer (E),
PWD Sub Division 2,
Edu. Elect. Edn. 1 Div. (N),
Sector-16, Rohini,
Delhi-110089.

Sub: Issue of FSC in r/o Govt. Senior Secondary School, Block (Educational building) at Sector-27, Rohini, Delhi.

Sir,

Kindly refer to online mail dated 24.03.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **12.06.2025** in presence of **Mr. Rahul Kumar J.E. (Elect.)**, **Mr. Parvesh Kumar (Elect. Supervisor)** to ascertain the availability and operability of the fire prevention and fire safety measures. The request for issuance of Fire Safety Certificate is rejected under rule 35 of DFS Rules, 2010 to following reasons:

1. Smoke management system is not provided in upper floors.
2. Hose reel provided but not functional.
3. Sprinkler systems are not provided in entire stilt area.
4. Yard hydrants and internal hydrant provided but not functional.
5. Terrace fire pump of 450 lpm is provided but not functional.
6. Terrace tank is found empty.
7. Standby power supply is not provided.
8. Fire control room is not provided.
9. Building is not matching the approved building plan.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR
Ph: 011-23414000
OK
Ch