



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/268

Dated 22/04/2025

To,

The Principal,  
Govt. Special School (Co-ed) for  
Children with Intellectual Disability  
Mayur Vihar, Delhi - 110091.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Govt. Special School (Co-ed) for Children with Intellectual Disability at Mayur Vihar, Delhi - 110091.**

Sir,

This has a reference to your Outdoor Diary No. 14521 dated 17/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 15/04/2025 in the presence of Mr. Rajender (Principal) and observed that building comprised of ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel not provided.
2. Terrace level fire pump capacity of 450 LPM not provided.
3. Overhead tank of capacity 10,000 liters not provided.
4. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
D/C DELHI FIRE SERVICE

**Copy to:-**

1. The Director of Education, (GNCT), Old Secretariat, Civil Line, Delhi - 110054.