

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2025/WZ/ 539 To, Dated: 20 06 2025

The Principal, Govt. Boys Sr. Sec. School, Bhorgarh, Delhi-110040.

Sub:- Renewal of Fire Safety Certificate in respect of Govt. Boys Sr. Sec. School (ID- 1310022) located at Bhorgarh, Delhi- 110040.

Sir,

This has reference to your application no. GBSSS/2025/468 dated 27/05/2025 received through outdoor diary no. 2228 dated 29/05/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 13.06.2025 to see the compliance of the requisite fire safety measures. Sh. Rambir (Estate Manager) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground and three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional and hose reel nozzle found missing at some places.

2. Internal hydrants found removed at upper floors and operating wheel found missing at ground floor.

3. Terrace level pumps found provided but not functional.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

Ph. 011-23414000

del n 1 = 2

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.