

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/School/2025/569

Dated:03 7 25

The Principal, GR International School, Pooth Khurd, Main Bawana Road, Delhi-110039.

Sub: Issue of FSC in r/o GR International School, Pooth Khurd, Main Bawana Road, Delhi-110039. Sir,

Kindly refer to online mail dated 28.05.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 26.06.2025 in presence of Mr. Umesh to ascertain the availability and operability of the fire prevention and fire safety measures. The request for issuance of Fire Safety Certificate is rejected under rule 35 of DFS Rules, 2010 to following reasons:

- 1. First Aid hose reel not provided.
- 2. Terrace fire pump capacity of 450 lpm is not provided.
- 3. 8000 ltrs Over Head water captive tank provided but use for domestic connection against the required capacity of 10,000 ltrs. for fire safety.
- 4. The required exit signage are not provided.
- 5. Approved building plans or as built plan from empanelled architect is not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg) PIRECTOR Ph: 011-23414000

or