



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

C/78



Dated: 26/05/25

No.F.6/DFS/MS/GH/NDZ/2025/ 256

To,

The Joint Commissioner (Lic.)  
1<sup>st</sup> floor Police Station Defence Colony,  
New Delhi

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Grace Guest House located at 1693, Arya Samaj Road, Karol Bagh, New Delhi-110005.**

Sir,

This has reference to MCD application ID No. 2025042907502 dated 29/04/2025 on the subject cited above. In this connection, the premises was re-inspected by the officer concerned of this department on dated 20/05/2025 of the above mentioned Guest House from fire safety point of view in presence of Mr. Umesh Singh (Manager). The Guest House building comprised of basement (other property), ground plus three upper floors. The following shortcoming was observed during the time of inspection.

1. First Aid hose reels are found removed at first and second floor.
2. PA system is not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

2. 22/5