



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/447

Dated: 07/04/2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Granmothers Arms Primary School** located at RZP-6, Raj Nagar, Part-2, New Delhi-110077, comprised of Ground + 02 upper floors but **school running at ground + one upper floor also submitted an affidavit dated 18.12.2024 regarding using ground & first floor for school activity and not to use terrace floor in any manner**, owned/occupied by Granmothers Arms Primary School, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on dated 26/03/2025 in the presence of Sh. Kumar Ashish (Caretaker) and that the school premise/building is fit for occupancy class "**Educational Group B**" (School) with effect from 07/04/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/04/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Principal, Granmothers Arms Primary School located at RZP-6, Raj Nagar, Part-2, New Delhi-110077

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-6

INSPECTION REPORT

1.	Name & address of the building	Granmothers Arms Primary School located at RZP-6, Raj Nagar, Part-2, New Delhi-77		
2.	Type of Occupancy	Educational (Group-B)		
3.	Building Comprised of	Ground & 02 upper floors but school is running at Ground & 1 st Floor only. Affidavit dated 18.12.24		
4.	Type of Case	New		
5.	Details of previous NOC No.	Nil		
6.	Fire Safety directives Letter No.	NBC/DOE Circular dated 01/03/2011		
7.	Date of inspection	26/03/2025		
8.	Name of the Inspecting Officer	ADO (DWK) Santosh Kumar		
9.	Name and designation of Officer from the building side	Sh. Kumar Ashish (Caretaker)		
10.	Year of Construction	2022		
11.	Applicant's letter No.	E-mail dated 05/02/2025 ashishdwivedi9@gmail.com		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	NBC/DOE Cir. Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	30 mtr	MR
	• Gate width	4.5 mtr	4.72 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5 mtr	1.5m (RCC) & 1.5m (Iron) upto FF	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	06 Nos	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A

84

64

V-7

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N-8

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	-NA-	CO ₂ Fire Extinguisher provided for electric panel	-NA-

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety as required under the Rules/DOE Circular, issuance of the fire safety certificate, under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval and signature please.

Santosh Kumar
03.04.25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (DWK)

DO (SW)

[Signature]
24/4/25

[Signature]
4/4/2025

Director

[Signature]
11/4/25

Any one

Sir, F.T letter is put up for your signature

Santosh Kumar
07.04.25

[Signature]
[Signature]