



FIRE SAFETY CERTIFICATE

Certified that the **Great Mission School located at B-26, West Vinod Nagar, I.P. Extn. (Near Badrinath Mandir), Delhi - 110092**, comprised of ground plus three upper floors (**School is running on Ground plus two upper floors only**) owned / occupied by **Great Mission School** was issued Fire Safety Certificate by this department vide letter No. F6/MS/DFS/2006/2119 dated 17/08/2006. The School building was re-inspected by the officer concerned of this department on 17/04/2025 in presence of Mrs. Maya Mathpal (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class Group B "**Educational Building**" with effect from 29/04/2025 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 29/04/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Great Mission School located at B - 26, West Vinod Nagar, I.P. Extn. (Near Badrinath Mandir), Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Great Mission School located at B-26, West Vinod Nagar, I.P. Extn. (Near Badrinath Mandir), Delhi - 110092.		
2	Building is comprised of	Ground plus three upper floors (School running on Ground plus two upper floors only)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/MS/DFS/2006/2119 dated 17/08/2006		
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	17/04/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/Laxmi Nagar		
9	Name of the designation of officer from the building side	Mrs. Maya Mathpal (Principal)		
10	Year of construction			
11	Applicant's letter no.	Outdoor Diary no. 14952 dated 25/03/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular 262-362 Requirements	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 mtrs.	6.0 mtrs.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	02 nos.	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 mtrs.	1.05 mtrs. & 0.70 mtr.	MR(old case)
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no	01 no	MR
	E Width of corridor	1.50 mtrs.	0.80 mtrs.	MR(old case)
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

6 A

5.	Fire Extinguisher:			
	A	Total numbers	08 nos.	08 nos.
	B	Types	CO ₂ & ABC	CO ₂ & ABC
	C	ISI marking	ISI Marked	ISI Marked
6	First-Aid-Hose Reel:			
	A	Total numbers of each floor	01 no	Provided
	B	Length of hose reel hose	30 m	Provided
	C	Nozzle diameter	05 mm	Provided
7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	N/A	N/A
	B	Location of main panel	N/A	N/A
	C	Location of repeater panel	N/A	N/A
	D	Alternate source of power	N/A	N/A
	E	Hooters	N/A	N/A
8	MOEFA:			
9	Public Address System:			
10	Automatic Sprinkler System:			
	A	Basement	N/A	N/A
	B	Upper floor	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A
11	Internal Hydrants:			
	A	Size of riser/down-comer	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A
	C	Hose box	N/A	N/A
12	Yard Hydrants:			
	A	Total number of hydrants	N/A	N/A
	B	Hose box	N/A	N/A
13	Pumping Arrangements:			
1	Ground level			
	A	Discharge of main pump	N/A	N/A
	B	Head of main pump	N/A	N/A
	C	Number of main pumps	N/A	N/A
	D	Jockey pump out put	N/A	N/A
	E	Jockey pump head	N/A	N/A
	F	Standby pump out put	N/A	N/A
	G	Standby pump head	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A
	I	Pump house access	N/A	N/A
2	Terrace Level			
	A	Discharge of pump	220 LPM	220 LPM
	B	Head of the pump	40 m	40 m
	C	Power supply	Required	Provided
	D	Auto starting of pump	Required	Provided

②

N/om

Great Mission School located at B-26, West Vinod Nagar, I.P. Extn. (Near Badrinath Mandir), Delhi – 110092.


14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	2500 liters	2500 liters
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

Note: School is running on Ground plus two upper floors only, third floor is being used for Guard residential purpose as per affidavit dated 08/04/2025.

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/MS/DFS/2006/2119 dated 17/08/2006, renewal under Rule 35(6) of the Delhi Fire Service rules 2010, is recommended.

No file is pending with me before disposal of this case.


 25/4/2025

Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO/Laxmi Nagar

D.O/EAST

DFA-PL
 21-04-2025
 C.F.O.
 23/4/2025
 Director
 24/4/25
 22/04/25
 An/LN