

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/BNQT/2025/SZ/ 37
To

Dated: 06./03./2025

The Addl. Commissioner of Police,
Lic/Branch 1st Floor PS Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o (Banquet Hall) M/s Green Apple Banquet located at A-1& A-2, Kh. No 8/16, Shyam Vihar, Phase-II, Najafgarh Delhi 110043.

Sir,

This has reference to with **MCD Portal ID 2025021802045 dated 18/02/2025** on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.03.2025 in the presence of Mr. Ranjeet Singh to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Service Staircase not provided to access the terrace.
2. Fire check door not provided.
3. First aid hose reel provided but found not functional.
4. Internal hydrant not provided inside the hall.
5. Terrace level fire fighting pump capacity 900 LPM could not be verified due to not accessibility to terrace level.
6. Overhead tank capacity 25,000 ltrs could not be verified due to not accessibility to terrace level.
7. Exit signage not provided at some places.
8. Banquet Hall is running in temporary ten shed structure. Hence two set of building plans through MCD is needed to be refer for further consideration in the matter.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

07/03/25