

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2025/NDZ/ 891

Dated: 14/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Green Day Public School located at E-Block, 5<sup>th</sup> Pusta, Sonia Vihar, Delhi-110094, building comprised of Ground plus one upper floor only, owned / occupied by Green Day Public School, was issued FSC vide letter No. F6/DFS/MS/School/2022/NDZ/686 Dt. 22/06/2022. The school building was re-inspected by the officer concerned of this department on 02/07/2025 in presence of Mr. Mathan Singh (Manager) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with D.O.E. Circular No. F16/Estate/CC/Fire Safety/2011/3298-3398 Dt. 01/03/11 issued by Director of Education and that the building is fit for occupancy class "Educational" (Group-B) with effect from 14/07/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

**Issued on** 14/07/2025 **at New Delhi by.**

(ATUL GARG)

**DIRECTOR**

**DELHI FIRE SERVICE**

Copy to :-

1. The Principal, Green Day Public School located at E-Block, 5<sup>th</sup> Pusta, Sonia Vihar, Delhi-110094.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).



# INSPECTION REPORT

- 7/4 -

1. Name & address of the building: Green Day Public School,  
E-Block, 5<sup>th</sup> Pusta, Sonia Vihar, Delhi-110094.
2. Building is comprised of : Ground plus one upper floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/NDZ/686 Dt. 22/06/2022
6. Fire Safety directives Letter No.: F16/Estate/CC/FireSafety/2011/3298-3398 Dt. 01/03/11
7. Date of inspection : 02/07/2025
8. Name of the Inspecting Officer : D.O. (E.D.)
9. Name and designation of Officer  
from the building side : Mr. Mathan Singh (Manager)
10. Year of Construction : 2006
11. Applicant's letter No. : Outdoor Dairy No. 2893 dt. 19/06/2025

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Circular Requirement	Provided at Site	Remarks
1	Access to building	6.0 M	6.0 & 4.0 M	MR
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 Nos.	02 Nos.	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	b. Width of Staircases	1.50 M	1.65 M & 1.10 M	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	01 Nos.	01 Nos.	MR
	d. No. of continuous staircases to terrace	1.50 M	1.50 M	MR
	e. Width of Corridor	1.0 M	1.0 M	MR
	f. Door size			
3	Compartmentation	N/A	N/A	N/A
	• Fire check Door	N/A	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
5	Fire Extinguishers	04 Nos.	08 Nos.	MR
	• Total Numbers	ABC & Co2	ABC & Co2	MR
	• Types	ISI Marked	ISI Marked	MR
	• IS Marking			



6	First-aid-Hose Reels			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	N/A	N/A	N/A
	• Number of Hydrants per Floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13				
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	N/A	N/A	N/A

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	
18	Refuge Area			N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	
19	Fire Control Room			N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2022/NDZ/686 Dt. 22/06/2022 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Ashok Kumar Jaiswal*  
3/7/2025

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : D.O. (East. Div.).

Dy C.F.O. 24

C.F.O.

11/7/2025

Director

Dir. P. S. Dept.

*[Handwritten signature]*