

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/BNQT/2025/SZ/ 69
To

Dated: 28/04/2025

The Addl. Commissioner of Police,
Lic Branch, 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Green Palms Banquet Hall, at B-17 Part-A
First Floor Jhilmil Industrial Area, Delhi 110095

Sir,

This has reference to your **MCD Portal ID 2025032804866 dated 02/04/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 12.04.2025 in the presence of Mr. Parminder (Maintenance) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Exit from one staircase from first floor is through kitchen area.
2. Two exits at ground floor and one exit at first floor found blocked.
3. Kitchen under staircase lobby is not allowed.
4. First aid hose reel provided but found not functional.
5. MOEFA found removed at some location of banquet hall.
6. Automatic sprinkler System provided but found not working.
7. Terrace level Fire fighting pumps found removed.
8. Overhead tank capacity 5000 ltrs found removed.
9. Temporary shed for office at terrace level not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

8/24/25