



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

do 37/5
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 467

Dated: 26/05/2025

To,

The Principal,
Greenfields Public School,
D – 161, Ganga Vihar,
Delhi - 110094.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Greenfields Public School located at
D – 161, Ganga Vihar, Delhi - 110094.**

Sir,

This has a reference to your Outdoor diary No. 431 dated 09/04/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 14/05/2025 in the presence of Mrs. Nupur Aggarwal (Incharge) and observed that building comprised of ground plus one upper floor.

Following shortcomings were observed during time of inspection:

1. Staircase width of 2.0 mtr. & 1.40 mtr. provided against the requirement of 1.5 mtr. each.
2. Continuous staircase to terrace not provided.
3. First-Aid-Hose Reel provided not provided.
4. Fire pump of 450 LPM not provided.
5. Overhead water storage tank of capacity 10000 liters not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(APUL GARG)

DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi-110002.