



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

C13

No. F6/DFS/MS/School/NDZ/2025/ 1109

Dated: 08/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Greenfields Public School** located at **D – 161, Ganga Vihar, Delhi - 110094**, comprised of **Ground plus one upper floor** owned/occupied by **Greenfields Public School** have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 19/08/2025 in the presence of Mr. Mithun Barsaley (Principal) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. and that **the school building is fit for occupancy class B “Educational Building”** with effect from 08/09/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 08/09/2025 at New Delhi by.

  
6/9/2025  
**VIRENDRA SINGH**  
**CHIEF FIRE OFFICER**  
o/c **DELHI FIRE SERVICE**

**Copy to: -**

1. The Director of Education, GNCT of Delhi, Old Secretariat, Civil Lines, Delhi-110054.
2. The Principal, Greenfields Public School located at D – 161, Ganga Vihar, Delhi - 110094.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

215

## INSPECTION REPORT

1	Name & address of the building	Greenfields Public School located at D - 161, Ganga Vihar, Delhi - 110094.		
2	Building is comprised of	Ground plus one upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	New Case		
5	Details of previous FSC	Nil		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	19/08/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Mithun Barsaley (Principal)		
10	Year of construction	--		
11	Applicant's letter no.	Email dated 12/08/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
	A Road width	6.0 meters.	8.0 meters.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases			
	a Upper floor	02 nos.	02 nos.	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 meters.	1.50 meters & 1.50 meter.	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no	01 no	MR
	E Width of corridor	1.50 meters.	1.70 meters.	MR
	F Door size	1.20 meter.	1.20 meter.	MR
3	<b>Compartmentation:</b>			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

(u) A




<b>5. Fire Extinguisher:</b>				
A	Total numbers	08 nos.	08 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	02 nos.	02 nos.	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
<b>8 MOEFA:</b>		N/A	N/A	N/A
<b>9 Public Address System:</b>		N/A	N/A	N/A
<b>10 Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2 Terrace Level</b>				
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	30 m	30 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters	10,000 liters	MR
15	<b>Exit Signage:</b>			
		N/A	N/A	N/A
16	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	<b>Standby Power Supply:</b>			
		N/A	N/A	N/A
18	<b>Refuge Area:</b>			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	<b>Fire Control Room:</b>			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2025/467 dated 26/05/2025 by this department has been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to **grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010** is recommended.

  
20/8/2025  
Signature of the Inspecting Officer  
Name Yashwant Singh Meena  
Designation ADO/Laxmi Nagar

D.O/EAST  
  
Dy C.F.O. (NDZ) 20/08/2025  
C.F.O.  
  
23/8/2025  
Principal Director

  
28/8/25

ADO (2N)

P.T.O