



C-37



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2025/NDZ/ 704

Dated: 23/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Greenfields Public School** located at **D-Block, Vivek Vihar, Delhi-110095**, comprised of ground plus one upper floor only owned/occupied Greenfields Public School was issued FSC vide letter No. F.6/ DFS MS/School/2022/NDZ/489 dated 06/05/2022. The premises was re-inspected by the officer concerned of this department on dated 15/05/2025 in the presence of Smt. Namita Jain, Principal of school and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01/03/2011 issued by the Director of Education and observed that the building/premises is fit for occupancy class '**Educational (Group-B)**' with effect from 23/05/2025 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on.....23/05/2025.....at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To:-

The Principal,
Greenfields Public School located at D-Block, Vivek Vihar, Delhi-110095

Copy to:-

The Dy. Director of Education at B-Block Anand Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhi.govt.nic.in

N/19

1. Name & address of the building : Greenfields Public School
D-Block, Vivek Vihar, Delhi-110095
2. Building is comprised of : Ground plus one upper floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2022/NDZ/489 dated 06/05/2022
6. Fire Safety directive letter No. : Circular No. 3298-3398 dated 01/03/2011
7. Date of Inspection : 15/05/2025
8. Name of the Inspecting officers : DO, A. K. Jaiswal & ADO (Shd.) Deepak Kumar
9. Name and designation of Officer
from the building side : Smt. Namita Jain (Principal)
10. Year of Construction : 1975
11. Applicant's letter No : email Dated 02/05/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Circular 2011 Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	06mtr.	06 mtr.	MR
	• Gate width	4.50 mtr	5.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr	1.25 mtr each	MR(old case)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases tototerrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 mtr	2.40 mtr & 3.10 mtr	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A

A

05.	Fire Extinguishers			
	• Total numbers	06 nos.	43 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	N/A	01 no.	N/A
	• Length of hose reel hose	N/A	30 mtr	N/A
	• Nozzle diameter	N/A	05 mm	N/A
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	450 lpm	N/A
	➤ Head of the Pump	N/A	40 mtr	N/A
	➤ Power supply	N/A	Provided	N/A
	➤ Auto Starting of pump	N/A	Provided	N/A

N/21

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	5,000 ltr	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Circular 3298-3398 dated 01/03/2011 issued by Director of Education, the FSC issued vide letter no. F.6/DFS/MS/School/2022/NDZ/489 dated 06/05/2022 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended..

Signature of the Inspecting Officer
 Name :- Deepak Kumar
 Designation :- A.D.O (Shd)

Signature of the Inspecting Officer
 Name :- A.K. Jaiswal
 Designation :- D.O (ED)

Dy CFO (MSD) 15/05/25

CFO 16/5/2025

Director 17/5/25

DO/ED 19.5.2025

Ado/shd

P.T.O.