

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2025/SZ/58

Dated: 31/01/2025

To

The Joint Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Geetanjali Inn at 3997-4000 & 4001 Gali School Wali, Barichi Ram Chander, Mohalla, Kaseuwalan, Pahar Ganj, Delhi

Sir,

This has reference with **MCD Portal 2025011400503 dated 14/01/2025** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 29/01/2025 in the presence of Mr. Salman Khan to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Smoke management system not provided as per clause 7.31 of UBBL 2016.
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE

[Handwritten signature]
30/1