



d82

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2026/ 352

Dated: -22/04/2026

To,

The Chairman,
NDMC, Palika Kendra,
Parliament Street,
New Delhi - 110001

Sub: Regarding renewal of FSC in r/o M/s Gulati Restaurant, Ground Floor, Shop No. 3,4,5,6, Pandara Road Market, New Delhi - 110003.

Sir,

Please refer to online application No. 2026032003202 dated 23/03/2026, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officers concerned of this department on 07/04/2026 in the presence of **Sh. Ankush, Manager** and following shortcomings were observed: -

1. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
2. Detectors found removed in the building.
3. Automatic operation of Fire Pump found removed.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

oreBl

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi - 110001.
2. The Manager, M/s Gulati Restaurant, Ground Floor, Shop No. 3,4,5,6, Pandara Road Market, New Delhi - 110003.