

C/250

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/2025/ 78

Dated 24/02/2025

To,
The Assistant Engineer (E), HC-4,
Health Maint. Elect. Division (Central),
PWD, Maulana Azad Medical College,
New Delhi - 110002.

Sub: Regarding renewal of Fire Safety Certificate for Guru Nanak Eye Centre, New Delhi.

Sir,

This has a reference to letter no. 23(8)/AE(E)/HMED(central)/HC- 4,PWD/2024- 25/18 dated 17/01/2025, on the subject cited above. In this regard, this is to inform you that the site was inspected by officers concerned of this department on 17/02/2025 in the presence of Sh. Susheel Kumar, JE (E) and following shortcomings were observed: -

1. Some detectors found nonfunctional.
2. PA system is not working properly.
3. Corridor found encroached by dumping of old furniture which may create hurdle at the time of any emergency for easy evacuation.

The above said shortcomings were also communicated on 25/01/2024.

In view of above, the case is rejected and fire safety certificate (FSC) cannot be issued at this stage.

Yours faithfully

(Arul Garg)
DIRECTOR
01123414000

Copy to:-

1. The Director, GNEC, New Delhi.
2. Executive Engineer (E), HMED (Central), PWD, Lok Nayak Hospital, New Delhi.
3. Junior Engineer (E), HC-4, HMED (C), PWD, GNEC, New Delhi.