

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2025/SZ/ 204
To

Dated: 02/05/2025

M/s Guru Nanak foundation,
15-16 Qutab Institutional Area,
Shaheed Jeet Singh Marg, Near Qutab Hotel
New Delhi 110067

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Guru Nanak foundation at
15-16 Qutab Institutional Area, Shaheed Jeet Singh Marg, Near Qutab Hotel New
Delhi 110067.

Sir,

This has reference with your letter no GNF/DFS/7491 dated 02/04/2025 received through outdoor diary no 123 dated 02/04/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 28/04/2025 in the presence of Mr. Rajender Singh (Admin) and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check doors & self closing device found removed at some place.
2. Fire fighting pumps are not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

du c