

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/Hospital/NDZ/2025/ 266

Dated 21/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Guru Nanak Eye Hospital** at **New Delhi** comprised of **OPD Block – Gr. + 02 Upper floor, Ward Block – Gr. + 02 Upper floor & O.T Block - Gr. + 01 Upper floors** was earlier granted FSC by this department vide letter No.F6/DFS/MS/hospital/NDZ/2020/552 dated 15/12/2020. **Now**, the premises was re-inspected by officers concerned of this department on **14/05/2025** in the presence of Sh. Sandeep Panwar, JE (E) & Sh. RK Meena, Admin, GNE hospital and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **E & I** Business and Institutional building with effect from 21/05/2025.....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 21/05/2025 at New Delhi by.

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, New Delhi.
2. The Medical Superintendent, Guru Nanak Eye Hospital, New Delhi.
3. The Assistant Engineer (E), HC-4, Health Maint. Elect. Division (C), PWD, Maulana Azad Medical College, New Delhi - 110002.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction, set back area, floor area, lift, electrical installation etc. shall be verified by the concerned authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

# INSPECTION REPORT

1. Name & address of the building : Guru Nanak Eye Hospital, New Delhi
2. Type of occupancy : Hospital Building  
OPD Block – Gr. + 02 Upper floor, Ward Block – Gr. + 02 Upper floor & O.T Block - Gr. + 01 Upper floor.
3. Type of case:- : Renewal
4. Details of previous NOC : No.F6/DFS/MS/hospital/NDZ/2020/552 dated 15.12.2020.
5. Fire safety directives No. : F6/DFS/MS/BP/Hospital/99/1353 dated 23/10/1999 for OT & ward block & even no. 1606 dated 24.01.1986( OPD) block
6. Date of inspection:- 14/05/25
7. Name of the inspecting officer : Sh. Ravinder Singh ADO/CC
8. Name & designation of officer From the building side : Sh. Sandeep Panwar , JE ( E) & Sh. RK Meena , Admin. GNE Hospital
9. Year of construction : 1986
10. Applicant's letter No : letter no. 23(8)/AE(E)/HMED(central)/HC-4,PWD/2025- 26/102 dated 15/04/2025.

Old Case( renewal)

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirements/ Existing fire safety arrangements      | Provided at site | Remarks MR/NMR |
|-------|---|--|------------------|----------------|
| 1.    | Access to Building  |  |                  |                |
|       | 1) Road width   | 09 mtr.  | 12 mtr.          | MR             |
|       | 2) Gate width   | 05 mtr.  | 06 mtr.          | MR             |
|       | 3)Width of internal road                                    | N/A  | N/A              | N/A            |
| 2.    | Number, Width Type & Arrangement of Exits.                  |  |                  |                |
|       | A. Number of staircases                                     |  |                  |                |
|       | 1. Upper floors( total )                                    | 07 No.   | 07 No.           | MR(Old Case)   |
|       | 2. Basements  | N/A  | N/A              | N/A            |
|       | B. Width of staircase                                       |  |                  |                |
|       | 1. Upper floors   | 2 mtr. & 1.2 mtr.(as per guidelines dated 24.01.86 ) | Provided         | MR             |
|       | 2. Basements  | N/A  | N/A              | N/A            |
|       | C. Protection of exits                                      |  |                  |                |
|       | 1. Fire check door  | Required   | Provided         | MR             |
|       | 2. Pressurization   | N/A  | N/A              | N/A            |
|       | D. No. of continuous staircase to terrace                   | 01 No  | Provided         | MR             |
|       | E. Width of corridor  | 2.4 mtr.   | Provided         | MR             |
|       | F. Door size( final exit )                                  | 02 Mtr.  | 02 Mtr.          | MR             |
| 3.    | Compartmentation  |  |                  |                |
|       | 1) Fire check door  | Required   | Provided         | MR             |
|       | 2) Sealing of electrical shafts                             | Required   | Provided         | MR             |
|       | 3) Fire rating of shaft door                                | N/A  | Provided         | N/A            |
|       | 4) Water curtain  | N/A  | N/A              | N/A            |
|       | 5) Fire Dampers   | N/A  | N/A              | N/A            |
| 4.    | Smoke Management System                                     |  |                  |                |
|       | 1) Basements  | N/A  | N/A              | N/A            |
|       | 2) Upper floors   | 12 ACPH  | Natural          | MR             |



N/32

|     |  |                       |                  |               |
|-----|--|-----------------------|------------------|---------------|
| 5.  | Fire Extinguishers                         |                       |                  |               |
|     | 1) Total numbers                           | 20 Nos.               | 30 Nos.          | MR            |
|     | 2) Types                                   | ABC & CO2             | ABC, CO2 & W.CO2 | MR            |
|     | 3) ISI marking                             | Required              | Provided         | MR            |
| 6.  | First-Aid Hose Reel                        |                       |                  |               |
|     | 1) Total number of each floor              | 02/3 No.              | 02/03 No.        | MR            |
|     | 2) Length of hose reel hose                | 30 m                  | 30 m             | MR            |
|     | 3) Nozzle diameter                         | 5 mm                  | 5 mm             | MR            |
| 7.  | Automatic Fire Detection & Alarming System |                       |                  |               |
|     | 1) Type of detectors                       | Required              | provided         | MR            |
|     | 2) Location of main panel                  | Gr. Floor             | Provided         | MR            |
|     | 3) Location of repeater panel              | Required              | Provided         | MR            |
|     | 4) Alternate source of power               | Required              | Provided         | MR            |
|     | 5) Hooter's Location                       | Required              | Provided         | MR            |
| 8.  | MOEFA                                      | Required              | Provided         | MR            |
| 9.  | Public Address System                      | Required              | Provided         | MR            |
| 10. | Automatic Sprinkler System                 |                       |                  |               |
|     | 1) Basement                                | N/A                   | N/A              | N/A           |
|     | 2) Upper floors                            | N/A                   | Provided         | N/A           |
|     | 3) Sprinkler above false ceiling           | N/A                   | Provided         | N/A           |
| 11. | Internal Hydrants                          |                       |                  |               |
|     | 1) Size of riser/down-comer                | 100 MM                | 100 MM           | MR            |
|     | 2) Number of hydrants per floor            | 03/02                 | 03/02            | MR            |
|     | 3) Hose box each floor                     | 03/02                 | 03/02            | MR            |
| 12. | Yard Hydrants                              |                       |                  |               |
|     | 1) Total number of hydrants                | 04                    | 04               | MR            |
|     | 2) Hose box                                | 04                    | 04               | MR            |
| 13. | Pumping Arrangement                        |                       |                  |               |
|     | 1) Ground level                            |                       |                  |               |
|     | a) Discharge of main pump                  | N/A                   | N/A              | N/A           |
|     | b) Head of main pump                       | N/A                   | N/A              | N/A           |
|     | c) Number of main pump                     | N/A                   | N/A              | N/A           |
|     | d) Jockey pump out put                     | N/A                   | N/A              | N/A           |
|     | e) Jockey pump head                        | N/A                   | N/A              | N/A           |
|     | f) Stand by pump output                    | N/A                   | N/A              | N/A           |
|     | g) Stand by pump head                      | N/A                   | N/A              | N/A           |
|     | h) Auto starting/Manual stopping           | N/A                   | N/A              | N/A           |
|     | 2) Terrace level                           |                       |                  |               |
|     | a) Discharge of pump                       | 900 LPM at each block | 4 Nos.900 LPM    | MR( old case) |
|     | b) Head of pump                            | 30 mtr.               | 30 mtr.          | MR            |
|     | c) Power supply                            | Required              | Provided         | MR            |
|     | d) Auto starting of pump                   | Required              | Provided         | MR            |

M/33

|     |  |               |               |           |
|-----|--|---------------|---------------|-----------|
| 14. | Captive Water Storage for Fire Fighting  |               |               |           |
|     | 1) Under ground tank capacity  | 1,50,000 ltr. | 1,50,000 ltr. | MR        |
|     | a) Draw-off connection   | Required      | Provided      | MR        |
|     | b) Fire service inlet  | N/A           | N/A           | N/A       |
|     | c) Access to tank  | Required      | Provided      | MR        |
|     | d) Over head tank capacity   | 20,000 Ltrs.  | Provided      | MR        |
| 15. | Exit Signage.  | Required      | Provided      | MR        |
| 16. | Provision of Lifts.  |               |               |           |
|     | a) Pressurization of lift shaft  | N/A           | N/A           | N/A       |
|     | b) Pressurization of lift lobby  | N/A           | N/A           | N/A       |
|     | c) Communication in lift car   | Required      | Provided      | MR        |
|     | d) Fireman's switch  | Required      | Provided      | MR        |
|     | e) Lift signage  | Required      | Provided      | MR        |
| 17. | Stand by Power Supply  | Required      | Provided      | MR        |
| 18. | Refuge Area  | N/A           | N/A           | N/A       |
|     | Total area location  | N/A           | N/A           | N/A       |
| 19. | Fire Control Room  |               |               |           |
|     | a) Detector system panel   | Required      | Provided      | MR        |
|     | b) Flow switch panel   | N/A           | N/A           | N/A       |
|     | c) PA system panel   | Required      | Provided      | MR        |
|     | d) Battery backup  | Required      | Provided      | MR        |
|     | e) Building floor plan   | Required      | Provided      | MR        |
| 20. | Special Fire Protection System for Protection of special Risk, if any: 1. Fire ext. & bucket |               |               | <b>MR</b> |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the above and deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No.F6/DFS/MS/hospital/NDZ/2020/552 dated 15.12.2020, under rule 35(6) of the Delhi Fire Service rules 2010 for the permanent structure only. Accordingly, DFA is prepared and put up for kind perusal/approval please.

Signature of the Inspecting Officer

Name :- Sh. Ravinder Singh  
Designation :- ADO (CC)

*Done*

*16/5/25*

*Dy. ADO (NDZ)*

*C.F.O.*

*16/5/25*

*16/5/2025*

*Ballu*