

C-41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2024/93

Dated: 31/01/2025

FIRE SAFETY CERTIFICATE

Certified that the **Guru Nanak Public School, located at West Avenue Punjabi Bagh, New Delhi-110026. (School ID- 1515110)**, comprised of 03 blocks (Ground Plus Three Upper floors(New Building),Ground Plus Two upper floor(Old Building), Ground + one Upper Floor (Office Block) all are inter connected was issued FSC vide letter No F6/DFS/MS/School/WZ/2021/976 dated 03/12/2021. The premises was re - inspected by the officer concerned by this department on 18/12/2024 in the presence of Smt Rema Punj (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 and the building/ premises is fit for occupancy class **"Educational" (Group -B)** with effect from 31.01.2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 31.01.2025 at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Principal, Guru Nanak Public School, Located at West Avenue Punjabi Bagh, New Delhi-110026. Email Id- gnpspbdelhi@gmail.com
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. Basement shall be used as per building by laws.

INSPECTION REPORT

1.	Name & address of the building	Guru Nanak Public School, located at West Avenue Punjabi Bagh, New Delhi-110026.
2.	Type of Occupancy	Educational (Ground + 3 Upper Floor New Building), (Ground + two upper floors Old Building, Ground + one upper floor office Block)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2021/976 dated 03/12/2021.
5.	Fire Safety directives letter No	Nil
6.	Date of inspection	19/12/2024
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Reema Punj (principal)
9.	Year of Construction	1979 (As per previous Inspection Report)
10.	Applicant's letter No.	Outdoor dairy No. 9998 dated 05/12/2024.

The School is running in a Building comprised of (Ground + 3 Upper Floor New Building), (Ground + two upper floors Old Building) & (Ground + one upper floor office Block). There is a basement of area (10 x 15) sqr ft. under the stage in open ground.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
--------	---	----------------------------------	------------------	----------------

1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	4.6m Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	3	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	2x1.51m, 1x1.10m, 1x1.13m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	1	Provided	MR
	e. Width of Corridor	1.5m	212cm & 148cm	MR (old Case)
	f. Door Size	1m	93cm (Old Case)	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	20 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	3	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	900LPM,450LPM	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2021/976 dated 03/12/2021 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

1/ADD/MN
12/2024

By CFO (WZ)

20/12/24

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

CFO/502-12D
dated 23/12/24

23/12/2024

CFO on leave
Director (DFS/MN)
24/12/24

ADP/MV

Sir, F.T is put up for
your kind personal & Sij please.

Director
mn

28/1/2025