

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/840

Dated: 27 / 11 /2025

To

The Principle, Guru Nanak Public School, Gurudwara Building, Sadar Bazar, Delhi Cantt. New Delhi – 110010.

Sub:- Renewal of Fire Safety Certificate in r/o Guru Nanak Public School, Gurudwara Building, Sadar Bazar, Delhi Cantt. New Delhi – 110010.

Sir,

Please refer to your letter No. GNPS/DC/2025-26/151 dated 19/09/2025 received in this department vide outdoor diary No. 4246 dated 22/09/2025, on the subject cited above. In this connection, the said school was visited by the officer concerned of this department on 03/11/2025 in the presence of Smt. Ramandeep Kaur (Principal) to verify the compliance of the shortcomings issued vide letter No. F.6/DFS/MS/School/2025/SZ/499 dated 09/06/2025 and observed that the shortcomings are still not complied.

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to comply with the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

Dy. Chief Fire Officer, SZ

Delhi Fire Service

1w

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.





GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ 499

Dated: <u>09</u>/<u>06</u>/2025

To

The Principal, Guru Nanak Public School, Gurudwara Building, Sadar Bazar, Delhi Cantt. New Delhi–110010.

Sub: Renewal of Fire Safety Certificate in r/o Guru Nanak Public School, Gurudwara Building, Sadar Bazar, Delhi Cantt. New Delhi-110010.

Sir,

Please refer to your letter No. GNPS/DC/2025-26/132 dated 28/04/2025 received in this department vide outdoor diary No. 1212 dated 01/05/2025, on the subject cited above. In this connection, the said school was visited by the officer concerned of this department on 23/05/2025 in the presence of Mr. Mukesh Kumar (Accountant) to verify the availability & operability of fire safety measures. During course of inspection, the shortcomings observed are as below.

- 1. Hose-reel provided found non-functional.
- 2. Terrace pump was not on auto mode.
- 3. Terrace tank provided found less than 10,000 liters capacity.

In view of the above, application for renewal of fire safety certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further action.

Yours faithfully,

(Virendra Singh) Chief Fire Officer Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054