



C 78

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6/DFS/MS/2025/School/WZ/ 444

Dated: 03/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Guru Premsukh Jain Model School** is running at ground and first floor of a building comprised of ground & two upper floors, second floor terrace two rooms located at **B-1, Bhagya Vihar, Jain Colony, Rani Khera, Delhi-110081** owned/ occupied by **Guru Premsukh Jain Model School** was granted NOC by this department vide letter No **F.6/DFS/MS/2021/School/WZ/779** dated **27.09.2021** for ground + 01 upper floors. The premises was re-inspected by the officer concerned of this department on **24.03.2025** in the presence of **Sh. Surender Pal Rana (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational for **Ground + 01 upper floor only** with effect from 03/04/2025 for a period of **three years**, subject to compliance of the conditions mentioned below

Issued on 03/04/2025 at New Delhi

(Atul Garg)

DIRECTOR

Ph; 011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Guru Premsukh Jain Model School, B-1, Bhagya Vihar, Jain Colony, Rani Khera, Delhi-110081.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. This NOC is valid only for G+01 floor.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT				
1. Name & address of the building	Guru Prem Sukh Jain Model School, B-1, Bhagya Vihar, Jain Colony, Rani Khera, Delhi-110081.			
2. Type of Occupancy	Educational			
3. Comprised of building	Ground + 02 upper floors, 2 nd floor terrace 02 rooms			
4. Type of Case	Renewal (School running at Ground + 01 upper floor only)			
5. Details of Previous NOC	F.6/DFS/MS/2021/School/WZ/779 dated 27.09.2021			
6. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011.			
7. Date of inspection	24.03.2025			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
9. Name and designation of officers From the building side	Sh. Surender Pal Rana (Principal)			
10. Year of Construction	2006, 2013 & 2022			
11. Applicant's letter No.	OD No.11696 dated 22.01.2025			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Cir.	Provided at site	Remarks MR/NMR
1.	Access to building	Accessible	Accessible	MR
	• Road width	Directly accessible	Directly accessible	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	01nos.	02nos.	MR
	• Upper Floors	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases	1.5m	1.10m each	MR(Old case)
	• Upper Floor	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits	-NA-	-NA-	-NA-
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	01nos.	Provided	MR
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	1m	1m	MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation	-NA-	-NA-	-NA-
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System	-NA-	-NA-	-NA-
	a) Basements	12 a/c per hour	Natural ventilated	MR
	b) Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers	07nos.	Provided	MR
	a) Total numbers	ABC/CO2	ABC/CO2	MR
	b) Types	ISI marked	Yes	MR
	c) IS marking	-NA-	-NA-	-NA-
6.	First-Aid Hose Reels	01nos.	Provided	MR
	a) Total numbers on each floor	30mm	Provided	MR
	b) Length of hose reel hose	5m	Provided	MR
	c) Nozzle diameter	-NA-	-NA-	-NA-

7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	2500ltr	10,000ltr	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-

✓

18. Refuge Area.			
a) Total Area	-NA-	-NA-	-NA-
b) Location	-NA-	-NA-	-NA-
19. Fire Control Room			
a) Detector System Panel	-NA-	-NA-	-NA-
b) Flow Switch Panel	-NA-	-NA-	-NA-
c) PA System Panel	-NA-	-NA-	-NA-
d) Battery backup	-NA-	-NA-	-NA-
e) Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education, and removal of shortcomings issued vide letter no. 832 dated 18.12.2024, the FSC issued vide letter no. F.6/DFS/MS/2021/School/WZ/779 dated 27.09.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

D.B Mukherjee
DO (NW)

DCFO 997-NW
Date 27/03/25

26/03/2025

By CDO (WZ)

28/3

29/3/2025

Director

Director

Fr letter is put up for 1st
perusal and signature please.

24/4/25