



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आपदापीन
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2026/ 354

Dated: 22/04/2026

To,

The Principal,
Guru Ram Dass Public Middle School,
Tagore Garden, New Delhi-110027.

Subject: - Regarding issuance of Fire Safety Certificate in r/o Guru Ram Dass Public Middle School located at Tagore Garden, New Delhi-110027.

Sir,

This has a reference to your application received through indoor diary no. 31 dated 01/04/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned school was visited by the officer concerned of this department on dated 13/04/2026 in the presence of Mr. Sardar Satpal Singh (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. One staircase of 1.42 mtr. provided against the requirement of 02 nos. of 1.5 mtr. each.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,


21/04/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service
o/c

Copy to :

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.