



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/CGHS/2025/SZ/ 398

Dated: 20 / 08 / 2025

To

The President/Secretary,  
Guru Ram Dass CGHS Ltd,  
Plot No. 03, Sector-22,  
Dwarka, New Delhi-110075

**Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Guru Ram Dass CGHS Ltd located at Plot No. 03, Sector-22, Dwarka, New Delhi-110075**

Sir,

This has reference to your letter No Nil dated 02/07/2025, received in this department vide outdoor diary No. 3518 dated 08/07/2025. In this connection, it is to inform you that the premise was re-visited by the officer concerned of this department on 26/07/2025 in the presence of Ms. Livleen Kaur (Secretary) to verify the compliance of shortcomings issued by this office vide letter No. F.6/DFS/MS/SZ/2024/223 dated 29/04/2024 and the status of shortcomings observed is as below.

S. No.	Shortcomings issued	Present Status
1.	The internal road around the buildings found encroached/blocked. The internal road must be free from any obstruction.	Not complied
2.	Smoke exhaust system found removed in basement.	Not complied
3.	Hose-reel hose and hydrants system found non-functional.	Not complied
4.	MOEFA found non-functional.	Complied
5.	PA system found non-functional.	Complied
6.	Automatic sprinkler system in basement found non-functional.	Not complied
7.	Terrace pump found non-functional.	Not complied

In view of the above, application for **renewal of fire safety certificate cannot be considered at this stage**. You are advised to rectify the above shortcoming as early as possible. The occupancy of the building in the absence of requisite fire protection measures/fire safety certificate shall be the sole responsibility and liability of the management committee.

Yours faithfully,

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

01/08/25

Copy to: -

1. The Deputy Director (Bldg.), DDA, Vikas Sadan, INA, New Delhi-110023