

c/101

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2025/ 28

Dated:-15/01/2025

To

The Manager  
M/s Gautam Residency,  
E-54, Greater Kailash Part 1,  
New Delhi.

Sub: Regarding issuance of FSC in r/o M/s Gautam Residency, E-54, Greater Kailash Part 1,  
New Delhi.

Sir,

This has reference to online id no. 2024122418336 dated 24/12/24, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 10/01/25 in the presence of Manager and following shortcomings were observed:-

1. Alternate staircase found removed at 1<sup>st</sup> floor and also not are available for occupants of second floor due to serving through guest room.
2. Fire check doors on the staircase are not provided as per G.N. 2019.
3. Smoke exhaust system not provided.
4. PA system found nonfunctional.
5. Hose reel & pump found nonfunctional.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

**Copy to :-**

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.