

C-30

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2025/SZ/625

Dated: 11 / 08 / 2025

To,

The Principal,
Gyan Jyoti Vidya Niketan,
W-21 Anupam Garden, Sadidulazab,
NEW Delhi 110068

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Gyan Jyoti Vidya Niketan,
at W-21 Anupam Garden, Sadidulazab, New Delhi 110068.


Sir,

This has reference with your letter, received through Email dated 10/07/2025 on the subject cited above. In this connection it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21/07/2025 in the presence of Mr. Navdeep (admin) and observed that the shortcoming intimated vide letter of even no 690 dated 08/10/2024 has not been complied yet. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Encl:- As above

Yours faithfully,


11. 08. 2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 690

Dated: 08 / 10 / 2024

To
The Principal,
Gyan Jyoti Vidya Niketan,
W-21, Anupam Garden,
Saidulazab New Delhi 110068

Sub: Issue of Fire Safety Certificate in r/o Gyan Jyoti Vidya Niketan, W-21, Anupam Garden, Saidulazab New Delhi 110068

Sir,

This is in reference to your Email dated 11-09-2024 on the subject cited above. In this connection, it is to inform you that the premise was inspected by the concern nominated authority of this department on 01/10/2024 in presence of Sh. Navdeep to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Width of staircase provided in block 1 & 2 is 1.50 mtr & 1.10 mtr respectively against the required width 1.50 mtr.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE