

c/45

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2025/SZ/ 579

Dated: 01/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **M/s Gyan Sagar Convent School** located at 516, Rajokri, Opp. Peer Baba, New Delhi-110038 comprised of Ground plus Two upper floor owned/occupied by Gyan Sagar Convent School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2019/SZ/2226 dated 27-11-2019. The premise was re-inspected by the officer concerned of this department on 24/04/2025 in the presence of Mr. Pradeep Yadav (Principal) and observed that school building have deemed complied with the fire prevention and fire safety arrangements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Group-B, Educational Building** with effect from 01/05/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/05/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Principal, Gyan Sagar Convent School located at 516, Rajokri, Opp. Peer Baba, New Delhi-110038
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry."

Name & Address of the Building

INSPECTION REPORT



2	Type of Occupancy	Gyan Sagar Convent School at 516, Rajokri		
3	Building Comprised of	Opp. Peer Baba, New Delhi-110038		
4	Type of Case	Educational, Group-B (School)		
5	Details of Previous NOC	Ground plus two upper floors		
6	Fire Safety Directives Letter No	Renewal		
7	Date of Inspection	F.6/DFS/MS/School/2019/SZ/2226 dated 27-11-2019 for G + 2		
8	Name of the Inspecting Officers	F6/DFS/MS/School/2022/SZ/1331 dated 15/12/2022 for G+1		
9	Name & Designation of Officers from the building side	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
10	Year of construction	24-04-2025		
11	Applicant letter No.	ADO (BCP)		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Mr. Pradeep Yadav (Principal)		
1	Access to Building.	2018		
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	DOE Circular Requirements	Provided at Site	Remarks MR/NMR
2	Number, width, type & arrangement of exits.	Accessible	Accessible	MR
		N/A	4.5 mtr	N/A
		N/A	N/A	N/A
	a) Number of Staircase			
	<ul style="list-style-type: none"> Upper floors. Basement floor. 	2 Nos	2 Nos	MR
	b) Width of Staircase	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors Basement floor 	1.5mtr	1.87mtr & 1.50mtr	MR
	c) Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	One	Provided	MR
	f) Door size	N/A	N/A	N/A
3	Compartmentation.	Classr'm=1m/1.2m Hall=1.5 mtr	Classroom=1m/1.2m Hall=1.5 mtr	MR
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH	N/A	N/A
5	Fire Extinguishers.	12 ACPH	N/A	N/A
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	8 Nos	10 Nos	MR
		ABC / CO2	ABC & CO2	MR
6	First Aid Hose Reels.	ISI marked	Provided	MR
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One	One	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
		N/A	N/A	N/A

2/19

9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40m	40m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	10,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

N/A

The Fire protection systems provided in the building/premise were test checked at random and found functional at the time of inspection.

Keeping in view of the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F&DFS/MS/School/2022/SZ/1331 dated 15/12/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Signature]
28/4/2023

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

[Signature]
28/4/23

[Signature]
28/4/2023

[Signature]
29/04/23

[Signature]
29/04/23

As approved, F.T. letter is put up for
your signature OI

[Signature]
01/05/23

[Signature]
11/5/23