



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2025/SZ/ 55

Dated: 06 /02 /2025

To

The Executive Engineer (Elect),
Central Public Works Department,
Safdarjung Hospital Electrical Division,
Safdarjung Hospital, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o 'H' Block located at Safdarjung Hospital Complex, New Delhi-110029

Sir,

This has a reference to your letter No. 19(1)/D.B./SJHED/2024-25/1689 dated 25/11/2024, received through outdoor diary No. 9630 dated 27/11/2024 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 24/01/2025 to verify the availability & operability of fire safety arrangements in the presence of Sh. Karan Singh (Fire Supervisor). During course of inspection, the shortcomings observed are as below.

1. First-Aid hose-reel provided found non-functional.
2. Automatic detection system provided found non-functional at some places.
3. Manually operated electrical fire alarm (MOEFA) found non-functional.
4. Hose-boxes near yard hydrant provided found empty (without branch & delivery hoses)
5. Exit signage found removed at some places.
6. Fireman's switch found non-functional & lift signage removed.

In view of above shortcomings, renewal of fire safety certificate cannot be considered at this state. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
Director

T. No. 011-23414000

6/1/25

Copy to: -

1. The Medical Superintendent, Safdarjung Hospital & Vardhman Mahavir Medical College, Safdarjung Hospital, New Delhi-110029.