

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2025/WZ/ / / 8

Dated: 21/3/25

To,

Ms Samriti Swami, Addl. GM (MKG HAFED Delhi), HAFED Warehouse Complex, B- Block, First Floor, Lawrence Road Industrial Area, Delhi-110035

Sub: - Regarding renewal of Fire Safety Certificate in r/o HAFED warehouse/ Cold Storage, Near Wazirpur Bus Depot-1, Lawrence Road Industrial Area, Wazirpur, New Delhi- 110035.
Sir,

This has reference to your email id dated 06/03/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said storage building has been carried out by officer concerned of this department on 10.03.2025 to see the compliance of the requisite fire safety measures. Sh. Surender Singh (SDO) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of 03 Blocks of Basements, Ground plus one upper floor each and the basement floor is interconnected with all blocks. Your request for renewal of FSC is rejected as the following shortcomings were observed:

- 1. Interconnected exit route between the blocks found locked/ blocked.
- 2. The exhaust fan for ventilation in basement found removed.
- 3. First aid hose reels found provided but not functional.
- 4. Automatic sprinkler system and detection system found removed at some places.
- 5. MOEFA found provided but not functional.
- 6. Main electric pump & Diesel D.G. driven pump and terrace level pump found provided but not functional.
- 7. Exit signages found removed at some places.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

In view of the above shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejects. The occupancy of the building in absence of requisite fire safety measures shall be at the risk & responsibility of the owner/ occupier.

Yours Fathfully

(Aful Garg)

PA. 011-23414000

(de A)