



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का
अमृत महोत्सव

Dated: 09/05/2026

No. F6/DFS/MS/EH/WZ/2026/ 451

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding renewal of Fire Safety Certificate in r/o Haldiram Products Pvt. Ltd, Located at 17-A Shivaji Marg, Main Najafgarh Road, Karampura Moti Nagar, New Delhi-110015.


Sir,

This has a reference to MCD application No. 2026041004779 dated 10/04/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department on dated 05/05/2026 in the presence of Mr. Pawan (Maintenance Head) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. The width of the alternate exit door was found to be less than the required 2.0 mtr.
2. Fire Check door (FCD) in the kitchen area was found removed.
3. The smoke management system in the basement and ground floor was found removed.
4. The smoke/heat detection system was found removed.
5. Concealed sprinkler plates were found permanently blocked with adhesive/putty, rendering the sprinklers non-functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(S. K. Dua)

Chief Fire Officer
Delhi Fire Service



Copy to :

1. The Owner/Occupier, Haldiram Products Pvt. Ltd, Located at 17-A Shivaji Marg, Main Najafgarh Road, Karampura Moti Nagar, New Delhi-110015.