C48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI – 110001

No: F6/DFS/MS/EH/NZ/2026/ 752 Dated: 09/ 11 /2026

FIRE SAFETY CERTIFICATE

Certified that **M/s Haldiram Products Private Limited** located at **Prop. No. D-48, GF, Satyawati Marg, Block 4, Roop Nagar, Kamla Nagar, Delhi - 110007**in a building comprised of Ground + 03 upper floor but restaurant at ground floor onlyhave complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 03.11.2026 in the presence of Mr. Mahender (Manager) and found that the said restaurant premises is fit for occupancy class **"Assembly"ground floor (restaurant)**with effect from .....09...../....11.....2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....09/11/2026...at New Delhi by

(M. K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service

01C82 06/11

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi - 02, w.e.f. ID No. 2026090510902 dated 05.09.2026 & 2026103111393 dated 31.10.2026.
2. The Licensee, M/s Haldiram Product Pvt. Ltd. At Prop. No. D-48, GF, Satyawati Marg, Block 4, Roop Nagar, Kamla Nagar, Delhi – 110007.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA Portal (https://www.delehlhlic.gov.in) along with a copy of this certificate, six months prior to its expiry.
9. This FSC is valid for the ground floor (Restaurant) only.

INSPECTION REPORT					
1	Name & address of the building		**M/s Haldiram Products Private Limited located at Prop. No. D-48, Satyawati Marg, Block 4, Roop Nagar, Kamla Nagar, Delhi - 110007.**		
2	Building is comprised of		**Ground + 03 upper floors (Restaurant at ground floor only) 1st to 3rd floor – (vacant)**		
3	Type of occupancy		Assembly Building-"Group-D"		
4	Type of case		New Case		
5	Details of previous FSC		Nil		
6	Fire safety direction letter no.		NBC Part IV & UBBL 2016		
7	Date of inspection		03.11.2026		
8	Name of the inspecting officers		ADO (MT)		
9	Name of the designation of officer from the building side		Mr. Mahinder (Manager)		
10	Year of construction		2023 (as per online application)		
11	Applicant's letter no.		Online application ID No. 2026090510902 dated 05.09.2026 & 2026103111393 dated 31.10.2026		
S.No	**Minimum Standards on fire Prevention and fire safety requirements U/R 33**		**Requirements**	**Provided at Site**	**Remarks MR/ NMR**
1	**Access To Building:**				
	Road width		Required	Provided	**MR**
	Gate width		NA	NA	NA
	Width of internal road		NA	NA	NA
2	**Number, Width, Type and Arrangement of Exits:**				
	A	Number of staircases	Restaurant at ground floor only		
		a Upper floor	NA	NA	NA
		b Basement	NA	NA	NA
	B	Width of staircases			
		a Upper floor	NA	NA	NA
		b Basement	NA	NA	NA
	C	Protection of exits			
		a Fire check door	NA	NA	NA
		b Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	NA	NA	NA
	E	Width of corridor	NA	NA	NA
	F	Door size	02 nos.-1.5 m each	Provided	**MR**
3	**Compartmentation:**				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	**Smoke Management System:**				
	A	Upper floors	Required	Provided	**MR**
	B	Basements	NA	NA	NA

5.	**Fire Extinguisher:**				
	A	Total numbers	06 nos.	Provided	**MR**
	B	Types	ABC& Co2	ABC& Co2	**MR**
	C	ISI marking	Required	Provided	**MR**
6	**First-Aid-Hose Reels:**				
	A	Total numbers at each floor	01 no.	Provided	**MR**
	B	Length of hose reel hose	30 mtr.	Provided	**MR**
	C	Nozzle diameter	05 mm	Provided	**MR**
7	**Automatic Fire Detection And Alarming System:**				
	A	Type of detectors	NA	Smoke type	NA
	B	Location of main panel	NA	Ground floor	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	Provided	NA
	E	Hooters Location	NA	Each floor	NA
8	**MOEFA:**		Required	Provided	**MR**
9	**Public Address System:**		NA	NA	NA
10	**Automatic Sprinkler System:**				
	A	Basement	NA	NA	NA
	B	Upper floor/ Gr. floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	**Internal Hydrants:**				
	A	size of riser/**down-comer**	100 mm	Provided	**MR**
	B	Number of hydrants per floor	01 no.	01 no.	**MR**
	C	Hose box	01 no.	01 no.	**MR**
12	**Yard Hydrants:**				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	**Pumping Arrangements:**				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i	Pump House Access	NA	NA	NA
	B	**Terrace level**			
	a)	Discharge of pump	450 LPM	Provided	**MR**
	b)	Head of the pump	40 m	Provided	**MR**
	c)	Power supply	Required	Provided	**MR**
	d)	Auto starting of pump	Required	Provided	**MR**

(M/s Haldiram Products Private Limited located at Prop. No. D-48, Kamla Nagar, Delhi - 110007)

14	**Captive Water Storage For Fire Fighting:**				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	20,000 ltrs.	Provided	**MR**
15	**Exit Signage:**		Required	Provided	**MR**
16	**Provision of Lifts:**				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	**Standby Power Supply:**		Required	Provided	**MR**
18	**Refuge Area:**				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	**Fire Control Room :**				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA-	NA	NA
	C	Pa system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	**Special Fire Protection Systems For Protection of Special Risks, If Any:**			NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the substantial compliance of minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to grant Fire Safety Certificate for ground floor (restaurant) under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for kind perusal, approval and signature please.

03/11/2026

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (MT)

DO (CN) 5/11

DyCFO/N2

3/11/2026

principal Director

DyCFO to move 4/11/2026

Dy CFO (N2)

4/11

DO (CN)

ADO/MT

DO (FPW) 5/11/26 Dated 03/11/26 04/11/26 06/11/26

F.T. letter is put up for signature, Please.

Kumar
06/11/2026

Dy. C.F.O. (H.Q.)

6/11/2026

MS Cell

09.11.2026

Uploaded
10/11/26