GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/SZ/2025/ 385

Dated: 25/09

/2025

To,

The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.

Sub:

Regarding renewal of FSC from fire safety point of view in respect of M/s Haldiram Marketing Pvt. Ltd, Located at F-126, Saheed Jeet Singh Marg, Katwaria Sarai New Delhi-110016.

Sir.

Please refer to your MCD online portal vide ID No. 2025083013018 dated 02/09/2025 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 15/09/2025 in the presence of Sh. Phool chand (unit manager) to check the provision of fire safety measures provided in the building.

During inspection, it has been observed that the said restaurant is running at ground floor in a building comprised of basement ground and first floor. Fire safety arrangements such as Fire Extinguishers, etc provided. However the following shortcomings were observed.

1. Smoke management system found remove.

2. First aid Hose reel is provided but not functional.

3. MOEFA is provided but not functional.

4. Main fire pump capacity of 225 LPM is provided but not on automode.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

irendra Singh Chief Fire Officer

1. The owner/occupier Ms Haldiram Marketing Pvt. Ltd, Located at F-126, Main Road, Copy To: -

Katwaria Sarai, Saheed Jeet Singh Marg, New Delhi-110016. MCD online portal vide ID No. 2025083013018 dated 02/09/2025.