



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2025/SZ/ 372

Dated: 07/11/2025

2173
विद्युत
भारत
एक कदम स्वच्छता की ओर

FIRE SAFETY CERTIFICATE

Certified that the premise of M/s **Haldiram Marketing Pvt. Ltd**, F-126, Ground floor, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi-110016, building comprised of Basement, Ground plus one upper floor, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2022/SZ/252 dated 07/09/2022. The restaurant premise was re-inspected by the officer concerned of this department on 25/10/2025 in the presence of Sh. Phool Chand Ahirwal (Store Manager) and found that said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "Assembly Group D" (Restaurant at ground floor only) with effect from 07/11/2025 for a period up to 31/03/2028 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/11/2025 at New Delhi by


(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service
01/11/25

Copy to: -

1. The Commissioner, MCD, 9th Floor, Civic Centre, Minto Road, New Delhi-110002
2. The Dy. Health Officer, MCD, Public Health Department, South Zone, Sri Aurobindo Marg, Green Park, New Delhi (w.r.t. online Id. No. 2025101314163 dated 14/10/2025)
3. Sh. Sanjeev Yadav, M/s Haldiram Marketing Pvt. Ltd, F-126, Ground floor, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi-110016

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. Basement shall be used as per Building Bye-laws.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-24

INSPECTION REPORT

1.	Name & address of the building	M/s Haldiram Marketing Pvt. Ltd, F-126, Ground floor, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi-110016		
2.	Type of Occupancy	Assembly, Group 'D' (Restaurant)		
3.	Building Comprised of	Basement, Ground + One upper floor but restaurant running at Ground Floor only.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/EH/2022/SZ/252 Dt. 07/09/22		
6.	Fire safety directives letter No.	Nil		
7.	Date of inspection	25/10/2025		
8.	Name of the Inspecting Officer	ADO (JKP)		
9.	Name and designation of Officer from the building side	Sh. Phool Chand Ahirwal (Store Manager)		
10.	Year of Construction	1993		
11.	Applicant's letter No./Online Appn.	No. 2025101314163 dated 14/10/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	9.0 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	Eating House at Ground Floor only		
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2 Exits	1.5 mtr each	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basement.	N/A	N/A	N/A
	• Ground floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos	Provided	MR
	• Types	CO ₂ / ABC	ABC & CO ₂	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

N-25

7.	Automatic fire detection and alarming system.			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Ground & Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	225 LPM	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2,500 ltr	Provided	MR
15.	Exit signage	Required	Provided	MR
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N-26


19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and **found functional at the time of inspection**. The shortcomings earlier issued by this department vide letter No. F6/DFS/MS/EH/SZ/2025/385 dated 25/09/2025 found rectified by the restaurant management.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/2022/SZ/252 dated 07/09/2022, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (JKP)

DO (SD) 
 30/10/25

~~DO (SZ)~~


 30/10/25
 A.K. MALIK
 Principal Director

Dy. CFO to Secy.

 01/11/25

~~Dy. CFO (SZ)~~


 3/11/25
 A.K. MALIK

DO (SD)


 6/11/25
 Ravinder Singh

ADD (JKP)

