



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव
C17

No. F6/DFS/MS/EH/WZ/2026/ 501

Dated: 21/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding renewal of Fire Safety Certificate in r/o Haldiram Marketing Pvt. Ltd. located at Shop No. 2/80 A, Plot No. 2, Road no. 80, Club Road, Punjabi Bagh, New Delhi-1100026.

Sir,

This has a reference to MCD application No. 2026042805903 dated 28/04/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department on dated 05/05/2026 in the presence of Mr. Rahul Yadav (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. Two staircase of width 1.5 mtr and 1.25 mtr provided against the requirement of 1.5 mtr each.
2. Hose reel hose provided but found not functional.
3. MOEFA provided but found not functional.
4. Internal Hydrant provided but found not functional.
5. Terrace pump provided but found not functional.
6. Overhead tank of capacity 10000 ltr provided against the requirement of 20000 ltr.
7. Exit Signage not provided at some locations.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


28/05/26

(S. K. Dua)

Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Owner/Occupier, Haldiram Marketing Pvt. Ltd. located at Shop No. 2/80 A, Plot No. 2, Road no. 80, Club Road, Punjabi Bagh, New Delhi-1100026.