



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2026/WZ/EH/ 528

Dated: 05/06/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Haldiram Products Pvt. Ltd. Anchor No. 03, & 20, Ground floor, D Mall, Netaji Subhash Place, Pitampura, New Delhi-110034, in a building comprised of 03 Tire Basement + Ground + 12 upper floors and Restaurant is running at Anchor No. 03, 20, Ground floor only, has already been issued FSC by this department vide letter No. F.6/DFS/MS/EH/WZ/2023/166 dated 30.05.2023. The premises was re-inspected by the officer concerned of this department on 25.05.2026 in the presence of Mr. Sonu Chaudhary (Duty Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class 'Assembly' Group D (Restaurant) for Anchor No. 03, 20, Ground floor only with effect from 05/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/06/2026 at New Delhi by


(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: Online MCD Portal ID-2026051206714 dated 12.05.2026.
2. The Manager, the M/s Haldiram Products Pvt. Ltd. Anchor No. 03, & 20, Ground floor, D Mall, Netaji Subhash Place, Pitampura, New Delhi-110034.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M/s Haldiram Products Pvt. Ltd. Anchor No. 03, & 20, Ground floor, D Mall, Netaji Subhash Place, Pitampura, New Delhi-110034.
2. Type of Occupancy	Assembly
3. Comprised of building	03 Tire Basement + Ground + 12 upper floors
4. Type of Case	Renewal (Restaurant is running at Anchor No. 03 & 20, Ground floor in a Mall)
5. Details of Previous NOC	F.6/DFS/MS/EH/WZ/2023/166 dated 30.05.2023
6. Fire Safety directives letter No	-NA-
7. Date of inspection	25.05.2026
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Wazirpur)
9. Name and designation of officers From the building side	Mr. Sonu Chaudhary (Duty Manager)
10. Year of Construction	2011 on MCD Portal
11. Applicant's letter No.	Online application No.2026051206714 dated 12.05.2026

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR issued FSC
1.	Access to building (D Mall, Netaji Subhash Place, Pitampura, No.F.6/DFS/MS/WZ/2025/360 dated 01.07.2025.)			
	• Road width	06m	30m Provided	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	-NA-	Restaurant is running at gr. floor	-NA-
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits	Common with the Mall		
	• Fire check door	Required in kitchen	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.5m & 2m	2.10m, 1.60m & 1.1m	MR
3.	Compartmentation	Common with the Mall		
	• Fire check door	Required in kitchen	Provided	MR
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System	Common with the Mall		
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	Mechanical/Natural ventilation	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	06nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels	Common with the Mall		

	• Total numbers on each floor	Near to restaurant	Provided by mall	MR
	• Length of hose reel hose	30mm	Provided by mall	MR
	• Nozzle diameter	5m	Provided by mall	MR
7.	Automatic fire detection and alarming system			Common with the Mall
	a) Type of detectors	-NA-	Provided	MR
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			Common with the Mall
	• Basement	-NA-	Provided by mall	-NA-
	• Ground & Upper Floors	-NA-	Provided by mall	-NA-
	• Sprinkler above false ceiling	-NA-	Provided by mall	-NA-
11.	Internal Hydrants			Common with the Mall
	• Size of riser/down-comer	-NA-	Provided by mall	-NA-
	• Number of hydrants per floor	-NA-	Provided by mall	-NA-
	• Hose Box	-NA-	Provided by mall	-NA-
12.	Yard Hydrants			Common with the Mall
	• Total number of hydrants	-NA-	Provided by mall	-NA-
	• Hose Box	-NA-	Provided by mall	-NA-
13.	Pumping Arrangements			Common with the Mall
	• Ground Level			
	➤ Discharge of main Pump	-NA-	4500lpm	-NA-
	➤ Head of Main pump	-NA-	65m	-NA-
	➤ Number of main pumps	-NA-	02nos.	-NA-
	➤ Jockey Pump out put	-NA-	180lpm	-NA-
	➤ Jockey pump head	-NA-	65m	-NA-
	➤ Standby Pump out put	-NA-	4500lpm	-NA-
	➤ Standby Pump Head	-NA-	65m	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	Provided	-NA-
	➤ Pump House Access	-NA-	Provided	-NA-
	Terrace level			
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of the pump	-NA-	-NA-	-NA-
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			Common with the Mall
	• Underground tank capacity	NA	2,50,000ltr	MR
	➤ Draw-off connection	-NA-	Provided by mall	MR
	➤ Fire service inlet	-NA-	Provided by mall	MR
	➤ Access to tank	-NA-	Provided by mall	MR
	• Overhead Tank capacity	10,000ltr	Provided by mall	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			Common with the Mall
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR

N/21

18.	Refuge Area.			
	➤ Total Area			
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room	-NA-	-NA-	-NA-
		Common with the Mall		
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/EH/WZ/2023/166 dated 30.05.2023 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Wazirpur)

DO (West)

CFB/122

Pr. Director

Ling
27/05/26

CFO to J. S. S.

28/05/26

CFO (West)

F.T. please.

Ling
01/06/26

ADO (West)

FT letter is put up for kind perusal
and signature please.

Ling
13/6/26

CFO

Ling
04/06/26
F.P. wingUploaded
05/06/26