



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001



No. F.6/DFS/MS/WZ/2025/ 362

Dated: 03/09/2025

To,
Mr. Sanjeev Yadav,
House No.90, 1st floor,
Ashoka Enclave Main Sector-35, Aman Nagar,
Faridabad,
Haryana-121003.

Sub: Renewal of FSC in r/o M/s Haldiram Marketing Pvt. Ltd. located at Plot No.B-1/F-10, M.C.I.E, Main Muthura Raod, Delhi-110044.

Sir,

This is reference to online application no. 2025080612281 dated 12.08.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 21.08.2025, in presence of Mr. Asfag Khan to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check door found removed.
2. 10,000 ltrs Over Head water captive tank provided against the required capacity of 20,000 ltrs.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2025080612281 dated 12.08.2025.