



No. F6/DFS/MS/EH/WZ/2026/523

Dated: 03/06/2026

FIRE SAFETY CERTIFICATE

Certified that the Haldiram Products Pvt. Ltd, Located at Ground Floor & Basement (for Storage purpose), 17-A Shivaji Marg, Main Najafgarh Road, Karampura Moti Nagar, New Delhi-110015, in a building comprised of Basement + Ground + 02 upper floors, owned/Occupied by Haldiram Products Pvt. Ltd., was earlier issued FSC by this department Vide letter no. F6/DFS/MS/EH/WZ/2023/196 dated 19/06/2023. The premises was re-inspected by the officer concerned of this department on 23/05/2026 in the presence of Mr. Nasir (Maintenance Supervisor) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Assembly" Group - D (Ground Floor & Basement (for storage purpose Only) for with effect from 03/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/06/2026 at New Delhi by.

Yours faithfully,


02/06/26

(S. K. Dua)

Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Commissioner, MCD, Civic Centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: Online MCD Portal ID-2026051206697 dated 12/05/2026.
2. The Owner/Occupier, Haldiram Products Pvt. Ltd, 17-A Shivaji Marg, Main Najafgarh Road, Karampura Moti Nagar, New Delhi-110015.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. This FSC is valid for Ground floor & Basement (for storage purpose only).

INSPECTION REPORT

1	Name & Address of the building	Haldiram Products Pvt. Ltd, Located at 17-A Shivaji Marg, Main Najafgarh Road, Karampura Moti Nagar, New Delhi-110015.		
2	Building is comprised of	Basement + Ground + 02 upper floors (Restaurant is running at Ground floor & Basement uses for storage purpose)		
3	Type of occupancy	Eating House /Assembly Occupancy		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/DFS/MS/EH/WZ/2023/196 dated 19/06/2023		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	23/05/2026		
8	Name of the inspecting officers	Mohd. Firoz Khan, ADO/MN		
9	Name of the designation of officer From the building side	Mr. Nasir (Maintenance Supervisor)		
10	Year of construction	2015 (As per MCD portal application)		
11	Applicant's letter no.	MCD Application No. 2026051206697 dated 12/05/2026		
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	BBL / NBC Requirements	Provide at site	Remarks MR/NMR
1	Access to Building			
	A Road width	09 m	60 m Provided	MR
	B Gate width	4.5 m	Provided	MR
	C Width of internal roads	As per sanctioned plan	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	A No. of staircase:			
	a) Upper floor	NA	NA	NA
	b) Basements	02	02 Provided	MR
	B Width of the staircase:			
	a) Upper floors	NA	NA	NA
	b) Basements	1.50 mtr.	Provided	MR
	C Protection of Exits			
	a) Fire check door	Required in Basement	Provided	MR
	b) Pressurization	NA	NA	NA
	D No. of continuous staircase to terrace:	NA	NA	NA
	E Width of the corridor	1.50 mtr.	Halls only	MR
	F Door size	2 m x 2 for restaurant	Provided	MR
3	Compartmentation:			
	A Fire check doors	Required	Provided	MR
	B Sealing of horizontal & vertical opening	Required	Provided	MR
	C Fire rating of shaft doors	Required	Provided	MR
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke management System:			
	A Basements	Required	Provided	MR
	B Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	A Total numbers	10 nos.	12 nos.	MR
	B Types	ABC & CO2	Provided	MR
	C ISI marking	ISI marked	Provided	MR

6	First Aid Hose Reel				
	A	Total no. at each floor	02	Provided	MR
	B	Length of hose reel	30m	Provided	MR
	C	Nozzle diameter	5mm	Provided	MR
7	Automatic Fire Detection and Alarm System				
	A	Type of detectors	Smoke & Heat	Provided	MR
	B	Location of main Panel	G.F	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	Required	Provided	MR
	E	Hooter's location	Required	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public Address System		Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	Required	Provided	MR
	B	Upper floor	NA	Provided	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants				
	A	Size of the riser/down comer	150 mm	Provided	MR
	B	No. of hydrants per floor	02	Provided	MR
	C	Hose box	02	Provided	MR
12	Yard Hydrants				
	A	Total no. of hydrants	04	Provided	MR
	B	Hose box	04	Provided	MR
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge of main pump	2280 LPM	Provided	MR
		b) Head of Main Pump	50 MH	Provided	MR
		c) Number of Main Pump	01	Provided	MR
		d) Jockey Pump out put	180 LPM	Provided	MR
		e) Jockey Pump Head	50 MH	Provided	MR
		f) Standby Pump out put	2280 LPM	Provided	MR
		g) Standby Pump Head	50 MH	Provided	MR
		h) Auto Starting/ Manual stopping	Required	Provided	MR
	B	Terrace Level			
		Discharge of Pump	900 LPM	Provided	MR
		Head of terrace pump	50MH	Provided	MR
		Power supply	Required	Provided	MR
		Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.				
	A	Underground tank capacity	50,000 ltrs	Provided	MR
	B	Draw off connection	Required	Provided	MR
	C	Fire Service Inlet	Required	Provided	MR
	E	Access to tank	Required	Provided	MR
	D	Overhead tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		Required	Provided	MR

18	Refuge Area			
A	location	N/A	N/A	N/A
B	Total area	N/A	N/A	N/A
19	Fire Control Room			
A	Fire Detection System panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	P A system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plan	N/A	N/A	N/A
20	Special Fire Protection for special risk if any			
A	Special Fire Protection system for Protection of Special Risk, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The shortcomings issued by this department vide letter no. F6/DFS/MS/EH/WZ/2026/451 dated 09/05/2026 have been rectified.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/WZ/2023/196 dated 19/06/2023 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Accordingly, DFA is prepared and placed opposite for perusal and approval please.

Note: - Last disposal date of the case is 10.06.2026.


Signature of the Inspecting Officer
Name: Mohd. Firoz Khan
Designation: ADO/Moti Nagar

D.O/WD 
25/05/2026

CFD/2
Pr. Director

Kirp
26/05/26

CFD to Secy

27/05/26

CFD (12)


E.T. please.
Kirp
29/05/26

ADOP(MN)
Sir it is put up for your kind perusal and signature please
Agree
11/06/2026

CFD (12)


Kirp
02/06/26

F.P. wing


Updated
03/06/26