





No F 6 / DFS / MS / EH / 2025 / WZ / 346

Dated 06/10/2025

FIRE SAFETY CERTIFICATE

Certified that M/s Haldiram Products Pvt. Ltd. located at 01, Raj Nagar Enclave, Pitampura, Delhi-110034 is running at Upper Ground Floor & First Floor in a building comprised of Basement, Stilt, Upper Ground floor plus three Upper Floors have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 20.09.2025 in the presence of Ms. Ruby (Manager) and found that the building/ premises is fit for occupancy "Assembly" (Group D) Sweet Shop at Upper Ground floor & Restaurant at First Floor with effect from 06/10/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on ...06/10/2025 at New Delhi by


(M.K. Chattopadhyay)
Dy. Chief Fire Officer


Copy to:-

1. The Commissioner, MCD, Delhi:- to ensure the occupancy as detailed above and deviation if any.
2. The Owner/ Occupier, M/s Haldiram Products Pvt. Ltd. located at 01, Raj Nagar Enclave, Pitampura, Delhi-110034.
3. MCD Portal ID No. 2025090813264.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for Upper Ground Floor & First Floor only.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MCD portal (<https://www.mcdonline.nic.in>) along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
10. The basement shall be used strictly as per building bye laws.

INSPECTION REPORT

1. Name & address of the building : M/s Haldiram Products Pvt. Ltd. located at 01, Raj Nagar Enclave, Pitampura, Delhi- 110034.
2. Type of Occupancy : Assembly (Sweet Shop at Upper Ground floor & Restaurant at 1st Floor)
3. Building Comprised of : Basement, Stilt, Upper Ground plus Three upper floors.
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 20/09/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers From the building side : Ms. Ruby (Manager)
10. Year of Construction : 2025 as per MCD Portal
11. Applicant's letter No. : MCD Application ID No. 2025090813264 dated 08/09/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ UBBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	Provided	MR
	Gate width	NA	Directly Accessible	NA
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	Upper Floors	02	Provided	MR
	Basements	NA	NA	NA
	b. Width of staircases			
	Upper Floor	2 × 1.5 m	Provided	MR
	Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2 × 1.5 m	Provided	MR
3.	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	NA	NA	NA
	Upper Ground floor	Required	Provided	MR
5.	Fire Extinguishers			
	Total numbers	06 Nos.	Provided	MR
	Types	ABC/Co2 Type	Provided	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	Type of detectors	NA	Smoke/ Heat	NA
	Location of Main Panel	NA	G.F.	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8.	MOEFA	Required	NA	NA
9.	Public Address System	NA	Provided	MR
			NA	NA

N-7

10.	Automatic Sprinkler System			
	Basement	NA	NA	
	Upper Floor	NA	Provided	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	100 mm	Provided	
	Number of hydrants per floor	01	Provided	MR
	Hose Box	01	Provided	MR
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	
	Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	450 lpm	Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	20,000 ltrs	20,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	Required	Provided	MR
	Fireman's Grounding Switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA

Special Fire Protection System for
protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is **recommended to grant Fire Safety Certificate** under Rule 35 of the Delhi Fire Service Rules, 2010.

Ado(BW)
22/9/21

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

DCFO/...
Date: 24/09/2021

Dy (B/W)

dy

CFO

26/9/2021

Principal Director

CFO to Secy.

26/9/21

CFO

ADO (B/W) Secy. I-T letter is kept for sign please

Ado(BW)

Dy (B/W)

dy

MS cell

uplaced