



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



NO.F.6/DFS/MS/WZ/EH/2025/274

Date: 18 / 06 / 2025

To

Mr. Sanjeev Yadav,
House No.90, 1st floor,
Ashok Enclave Main, Sector-35,
Amar Nagar, Faridabad, Haryana,
121003.

Sub:- Issue of fire safety certificate r/o M/s Haldiram Marketing Pvt. Ltd., located at Shop No.1509, GF, FF, SF, Third Floor, Bhishmpitha Mah Marg, Wazir Nagar, Delhi-110003.

Sir,


This is refer to online application no. 2025051908684 dated 22.05.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **03.06.2025**, in presence of **Mr. Sandeep Chatterjee**, to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Alternate exit of 1.5m not provided.
2. Alternate staircase is not continuous to terrace level.
3. FCD not provide in staircases.
4. Smoke management system /ventilation is not provided in upper floors & staircases.
5. Fire water pump house having pumps one electric, one D.G. pump capacity of 2280 LMP & one jockey pump capacity 180 LMP not provided.
6. Underground tank capacity of 1, 00,000ltr not provided.
7. Lift Signage are not provided.
8. Building is not matching with the approved building plans as staircases flights are not in same enclosure.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I"/MHA Portal and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully



(Virendra Singh)
Chief Fire Officer

Copy to:-

1. MCD Portal ID-2025051908684 dated 22.05.2025.
2. MCD Portal ID-2025052609084 dated 27.05.2025.