

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2025/SZ/154

Dated: 07/04/2025

To

The Joint Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Hans International
Guest house, 7965 Gali No 6, Arakashan Road, Pahar Ganj, Delhi

Sir,

This has reference with **MCD Portal 2025030903149 dated 09/03/2025** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 02/04/2025 in the presence of Mr. Santosh Kumar (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Smoke management system found removed.
2. First aid hose reel provided but found non-functional.
3. Terrace level fire fighting pump capacity 180 LPM provided but found non-functional.
4. Exit signage found removed at some places.
5. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE