



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

75  
आज़ादी का  
अमृत महोत्सव

No. F. 6. / DFS / MS / BP /CGHS/2025/ 193

Dated: 28 /04/2025

To,

The Executive Engineer, (Bldg) HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> Floor, Civic Centre,  
Minto Road, New Delhi-110002.

**Sub: Online building plans belonging to Bharat Jagriti CGHS Ltd., Plot No. 22  
Sector-12, Dwarka, New Delhi for addition and alteration.**

Sir,

Please refer your online ID No. 10119924 dated 14.04.2025 on the subject cited above. In this connection it is to inform you that the premises was visited by officer concerned of this department and observed following shortcomings:

1. Width of staircases found varied from 110 cm to 115 cm.
2. 6.0 meter fire tender movement road found encroached.

Therefore, proposal is rejected.

Yours faithfully

(ATUL GARG)  
DIRECTOR

Ph/011-23414000