

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/GH/2025/SZ/ 152

Dated: 04/04/2025

To

The Joint Commissioner of Police (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Hare Krishna Guest House  
at 1572-73, Main Bazar, Pahar Ganj Delhi 110055.

Sir,

This has reference with **MCD Portal 2025031503581 dated 15/03/2025** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 27/03/2025 in the presence of Mr. Uma Shankar (Front Office) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Smoke ventilation system not provided as per clause 7.31 of UBBL 2016.
2. First Aid hose reel hose provided but found not working.
3. Terrace level fire fighting pump capacity 225 LPM provided but found not working.
4. Exits signage found removed at some places.
5. The occupancy above 3<sup>rd</sup> floor of the building is not allowed as per the clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE