



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 11

Dated: 06/01/2025

To

The Joint Commissioner of Police (Lic.),
First Floor, Police Station Defence Colony,
Andrews Ganj, New Delhi-110049

Sub: Regarding Renewal of Fire Safety Certificate in r/o Hare Rama Guest House located at T-416 & T-298, Main Bazar, Pahar Ganj, New Delhi.

Sir,

Please refer to the online ID No. 2024122018227 dated 20/12/2024, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 30/12/2024 in the presence of Mr. Galib Reza (Rec. Manager). During the inspection, the shortcomings observed are as below.

1. Portable fire extinguishers provided found unrefilled and corroded.
2. First-aid hose-reel provided found non-functional.
3. MOEFA provided found non-functional.
4. Terrace fire pump found non-functional and rusted.
5. Overhead captive water storage for fire-fighting tapped for other use/purpose.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of owner/occupier. The licensing/statutory authority may take suitable and necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Ms. Shalini Aggarwal M/s Hare Rama Guest House located at T-416 & T-298, Main Bazar, Pahar Ganj, New Delhi-110055